

GENERAL NOTES


1. ALL DRAINAGE PIPING 3" AND SMALLER SHALL BE SLOPED AT 1/4" PER FOOT.
2. ALL DRAINAGE PIPING 4" AND LARGER SHALL BE SLOPED AT 1/8" PER FOOT.
3. ALL CONDENSATE DRAINAGE (CD) PIPING SHALL BE SLOPED AT 1/8" PER FOOT.
4. ALL STORM DRAIN (SD) AND OVERFLOW STORM DRAIN (OSD) PIPING SHALL BE SLOPED AT 1/8" PER FOOT.
5. NO PIPING SHALL BE DIRECTLY EMBEDDED IN CONCRETE OR MASONRY WALLS.
6. THE CUTTING, NOTCHING AND BORING OF HOLES IN FLOOR JOISTS AND WALL STUDS SHALL BE IN ACCORDANCE WITH THE UNIFORM BUILDING CODE 1997 EDITION, VOLUME NO. 2, CHAPTER 23, SECTION 2320.

SHEET NOTES

- 1 1/2" HOT AND COLD WATER DOWN.
- 1/2" HOT AND COLD WATER UP TO LEVEL 2.
- 1" COLD WATER UP TO LEVEL 2.
- 1-1/2" COLD WATER DOWN.
- 2" COLD WATER DOWN.
- 2" COLD WATER HEADER.
- 1/2" TYPE L SOFT COPPER BELOW GRADE FROM SLOAN VACUUM BREAKER TRAP PRIMER MODEL NO. VBF-72-AT TO FLOOR DRAIN.
- 1/2" COLD WATER DOWN.
- 2-1/2" COLD WATER BELOW GRADE.
- 6" FIRE PROTECTION LINE BELOW GRADE.
- 2-1/2" COLD WATER UP FROM BELOW GRADE.
- FIRE PROTECTION RISER.
- 1/2" HOT AND COLD WATER DOWN FROM LEVEL 2.
- SHUT OFF VALVES ABOVE CEILING WITH ACCESS PANEL TO MATCH CEILING CONSTRUCTION.
- NIBCO GLOBE STYLE BALANCING VALVE MODEL NO. S1710-1/2", SET FOR 0.5 GPM.
- 2" COLD WATER AND 3/4" HOT WATER DOWN FROM LEVEL 2.
- 2" COLD WATER, 1-1/4" HOT WATER, AND 3/4" HOT WATER RETURN UP TO LEVEL 2.

WATER SUPPLY PIPING PLAN BUILDING II LEVEL 1

SCALE: 3/16"=1'-0" 26231



REVISIONS
 5-21-04 PLAN CHECK
 6-23-04 PLAN CHECK

CONSULTANT
JMA ARCHITECTURE STUDIOS
 10150 GOVERNOR CROSS DRIVE LAS VEGAS, NEVADA 89134 (702) 737-1833

CITY OF LAS VEGAS
DOWNTOWN SENIOR SERVICES CENTER
 NEIGHBORHOOD SERVICES

BID SET

OWNER: CITY OF LAS VEGAS
 DEPARTMENT OF PUBLIC WORKS
 ARCHITECTURAL SERVICES

400 EAST STEWART AVENUE
 LAS VEGAS, NEVADA 89101
 PHONE (702) 258-6666
 FAX (702) 382-3232
 TDD (702) 388-1030
 DRAWN: CA
 FILE: P3010UG
 DATE: September 8, 2004
 SCALE: 3/16"=1'-0"
 BID NO: 04B3401
 CLV DWG NO: 501-281
 WATER SUPPLY PIPING PLAN
 LEVEL 1

PROJECT NO.: 23154.30
 DESIGNED BY: J. DARRIS
 CHECKED BY: R.S.HARRIS
 DRAWN BY: C.SADLER
 PM: J. HEAL

P3.01