







①	AIR CONDITIONER / HEATER UNIT (SEE SPEC DIV 43).	⑬	IRRIGATION TIMER
②	SPLIT FACED 8"x 8"x 16" PIGMENTED CMU WALLS SOLID GROUT ALL CELLS. CONTRACTOR TO SUBMIT COLOR SAMPLES.	⑭	BOOSTER PUMP STARTER
③	ROLLING SERVICE DOOR (SEE SPEC DIV 62).	⑮	E.F. AND LOUVER STARTER
④	REMOTE TERMINAL UNIT (RTU)	⑯	OUTSIDE LIGHT SWITCH BOX
⑤	SWITCHGEAR MCC IN COMMING COMPARTMENT (PROVIDED BY L.V.V.W.D.)	⑰	PLC CABINET
⑥	MOTOR CONTROL CENTER (MCC) INSTRUMENT COMPARTMENT (PROVIDED BY L.V.V.W.D.)	⑱	FLOW INDICATOR
⑦	30KVA, 3Ø TRANSFORMER		A/C THERMOSTAT
⑧	PANEL "A"		
⑨	NITROGEN DRAWDOWN ASSY		
⑩	NITROGEN TANK		
⑪	FLOOD LIGHT		
⑫	TRANSFORMER DISCONNECT SWITCH (PROVIDED BY L.V.V.W.D.)		



original Signed
10-5-94



DRAWING NUMBER
713
REF. SHEET NO. C14
SHEET 14 OF 29