



SYMBOL AT EACH SERVICE INDICATES THE FOLLOWING BASED ON RECORD INFORMATION:

- ⓪ EXISTING SWG SERVICE. NO WORK REQUIRED.
- ① ABANDON 1" PE STUB WHEN MAIN IS ABANDONED.
- ② INSERT 1/2" PE INTO EXISTING 1/2" THIN WALL PVC WHEN PRACTICAL AND POSSIBLE. IF ANODE RISER, REPLACE WITH ANODELESS RISER. TIE INTO NEW 2" PE MAIN.
- ③ TIE-OVER 1" PE TO NEW 2" PE MAIN.
- ④ TIE-OVER 1" PVC SCHEDULE 40 TO NEW 1" PE.

LEGEND	
	Proposed gas main
	Existing gas main
	Right of way
	Curb/Gutter

CALL BEFORE YOU DIG  
CAN YOU DIG IT!  
1-800-227-2600  
(48 Hrs. Advance Notice Required)

AREA 1 LV 16

REF-ALIGNED TIE-IN LOCATION		DATE: 7-24-03		AS-BUILT DRAWING-PRESSURE TEST DATA				VISUAL INSPECTION CERTIFICATION				CONSTRUCTION		ISOLATION AREA		W. R. NO.		ENGINEER/TECHNICIAN			
DESCRIPTION		BY	DATE	APPROV.	PIPE DIA.	TEST MEDIUM	TEST METHOD	I HAVE VISUALLY INSPECTED ALL HEATED FUSIONS, SOLVENT CEMENT, MECHANICAL JOINTS, AND WELDS THAT I HAVE PERFORMED				INSPECTOR	FOREMAN	REVIEWED BY	15	0306664258	BOB MIDDAG				
REVISIONS		SEE SHEET 1			PIPE LENGTH	<input type="checkbox"/> AIR	<input type="checkbox"/> GAUGE	NAME				PERMIT INFORMATION		LOCATION		TITLE		ACCOUNT REP.			
					PIPE TYPE	<input type="checkbox"/> NITROGEN	<input type="checkbox"/> CHART	DATE				Tax Code Area-02-0200		ATLAS #/TILE #		F-NDOT-RANCHO DR. OVERLAY		PROJECT CONTACT			
					HIN. DURATION	<input type="checkbox"/> WATER	<input type="checkbox"/> GAUGE/ PRESS REC SW	START				CITY OF LAS VEGAS		x615y524		SUNSET DR. TO MELODY LN.		BOB MIDDAG			
					TEST PRES. (PSIG)	<input type="checkbox"/> SOAP		END				NDOT						PHONE 365-2071			
					TIME			AS-BUILTS ACCEPTED BY										PHONE 365-2071			
					DATE			DATE										DATE 7/9/03			
					PERFORMED BY			POSTING DATE										DWN. BY R. SKROVE			
								POSTING Q'D BY										CHKD. BY			
																		APPVD. BY			

