

FLUORESCENT FIXTURE
 FLUORESCENT FIXTURE
 FLUORESCENT FIXTURE
 DOWNLIGHT FIXTURE.
 FLOOD LIGHT
 WALL MOUNTED FIXTURE.
 EXIT SIGN W/ DUAL HEADS - UNIVERSAL MOUNTED
 FLUORESCENT FIXTURE CONNECTED TO EXISTING BUILDING
 COMPUTER AIDED DISPATCH LIGHTING CONTROLLER AND TIME DELAY
 FLUORESCENT FIXTURE WITH EMERGENCY BATTERY UNIT
 LETTER INDICATES LIGHT FIXTURE AS INDICATED ON FIXTURE SCHEDULE
 SINGLE POLE SWITCH • +48" UNLESS NOTED.
 3-WAY SWITCH • +48" UNLESS NOTED
 DUPLEX RECEPTACLE • +18" UNLESS NOTED.
 GFI DUPLEX RECEPTACLE UNLESS NOTED +42"
 DOUBLE DUPLEX RECEPTACLE • +18" UNLESS NOTED.
 TELEPHONE OUTLET • +18" UNLESS NOTED.
 DATA OUTLET • +18" UNLESS NOTED.
 LANDLINE VOCAL SYSTEM
 SPECIAL RECEPTACLE
 PANEL BOARD
 DUCT DETECTOR
 SMOKE DETECTOR
 TV OUTLET
 LIGHTING SENSOR
 VOLUME CONTROL
 RADIO VOCAL SYSTEM SPEAKER
 COMBINATION FIRE ALARM HORN WITH ADA STROBE.
 THERMOSTAT OUTLET • +48" UNLESS NOTED.
 JUNCTION BOX.
 FUSED DISCONNECT SWITCH.- SIZE AS INDICATED.
 MECHANICAL EQUIPMENT CONNECTION, SEE SCHED. ON MECH. PLAN

INDICATES AMERICAN DISABILITIES ACT
ABOVE FINISHED FLOOR
CONDUIT W/ FULL LINE ONLY
ELECTRICAL CONTRACTOR
EMERGENCY
FURNISHED BY OTHERS
GROUND FAULT CIRCUIT INTERRUPTER
PANEL
UNLESS NOTED OTHERWISE
WEATHER-PROOF (NEMA 3R)
MOUNTING HEIGHTS ARE TO CENTERLINE OF DEVICE
ABOVE FINISH FLOOR OR FINISH GRADE. VERIFY
EXACT MOUNTING HEIGHTS PER ADA REQUIREMENTS.

② LANDLINE VOCAL SYSTEM SPEAKER - QUAM *C10X/BUW/ (SPEAKER LINE LANDLINE VOCAL SYSTEM LINE MATCH TRANSFORMER AND GRILL) WITH QUAM ERD-81ST ENCLOSURE WITH QUAM SSB-2 SPEAKER SUPPORT BRIDGE. CENTER ALL (WHITE) GRILLS IN CEILING TILES.

③ RADIO VOCAL SYSTEM SPEAKER - QUAM *C10X/BUW/ (SPEAKER LINE LANDLINE VOCAL SYSTEM LINE MATCH TRANSFORMER AND GRILL) WITH QUAM ERD-81ST ENCLOSURE WITH QUAM SSB-2 SPEAKER SUPPORT BRIDGE. CENTER ALL (WHITE) GRILLS IN CEILING TILES.

④ SPEAKER VOLUME CONTROL - ATLAS/SOUNDOLIER ATT5 SET IN FLUSH 2-GANG J-BOX WITH SINGLE GANG RING AT +48" ABOVE FINISHED FLOOR.

⑤ (2) HUBBELL HXJ6B ANGLED RJ45 (2) HUBBELL HXJUGY RJ-11 ANGLED JACKS, WITH HUBBELL FACE PLATE INFW FRAME WITH (2) IM2KA15W MODULES SET IN 2 GANG J-BOX WITH SINGLE GANG RING WITH (2) 4 PAIR CATEGORY 6 WIRING TERMINATED TO T568B WIRING STANDARD (DATA) AND (2) 4 PAIR CATEGORY 3 TERMINATED TO SPRINT TELEPHONE SPECIFICATIONS. 48" UNO. (CERTIFY DATA TERMINATIONS)

⑥ (1) HUBBELL SFFWX COAX JACK, (3) HUBBELL BLANK JACK WITH HUBBELL FACE PLATE INFW FRAME WITH (2) IM2KA15W MODULES SET IN J-BOX WITH RG-6/U 75 OHM COAX CABLE TERMINATE AT COUPLER AND TTB PER COX CABLE SPECIFICATIONS.

ABF CONSULTING ENGINEERS

 Las Vegas, Nevada 89103
Tel: (702) 248-0338
Sparks, Nevada 89431
Tel: (775) 674-2222
Phoenix, Arizona 85014
Tel: (602) 274-1801

THE ENGINEER ACCEPTS NO LIABILITY OR RESPONSIBILITY FOR THESE DOCUMENTS UNLESS HIS ORIGINAL SEAL AND SIGNATURE IS AFFIXED TO THEM.

- ① CATALOG NUMBER INDICATES BASIC FIXTURE TYPE REQUIRED. VERIFY WITH MANUFACTURER TO INCLUDE ALL ACCESSORIES FOR THIS PROJECT.
- ② VERIFY WITH ARCHITECTURAL REFLECTED CEILING PLANS, SECTIONS, ETC. PRIOR TO ORDERING FIXTURES.
- ③ DUPLEX RECEPTACLE MOUNTED AT +84"
- ④ FEMALE PLUG-LEVITON 15A-250V. GROUND NEMA 6-15R WIRED FOR 12 VOLTS ON TWO PRONGS AND GROUND.
- ⑤ TRUCK MOUNTED REVERSE SERVICE (15A-12VOLT) WITH AUTO EJECT CAPABILITY (BY OWNER)
- ⑥ CONTRACTOR TO PROVIDE 10/2 AMP CHARGER FOR 55 AMPS STARTER (SOLAR MODEL # 10260-6/12V). PROVIDE 12"x12"x3/4" MELAMINE WALL SHELF AND SUPPORT AT 84" FOR BATTERY CHARGER (TYP) 1 EACH PER FIRE STATION.

ED.1	SYMBOL LIST & FIXTURE SCHEDULE
ED.2	SPECIFICATION HIGHLIGHTS
ED.3	SINGLE LINE DIAGRAMS & SCHEDULES
ES.2	ELECTRICAL SITE PLAN STATION #2
ES.1	ELECTRICAL SITE PLAN STATION #1
ES.9	ELECTRICAL SITE PLAN STATION #9
EI.2	LIGHTING PLAN STATION #2
E2.2	POWER & AUXILIARY PLAN STATION #2
E1.19	LIGHTING PLAN STATIONS #1,9
E2.19	POWER & AUXILIARY PLAN STATIONS #1,9



AS BUILT INFORMATION WAS PROVIDED
BY THE CONTRACTOR. WESTAR
ARCHITECTURAL ASSUMES NO LIABILITY
FOR ACCURACY OF ITS CONTENTS.

**A FACILITY IMPROVEMENT FOR:
FIRE STATION 2,7, & 9
LAS VEGAS, NEVADA**

PROJECT NUMBER	01833		NUMBER	REVISION DESCRIPTION	DATE
	DRAWN BY	CHECKED BY			
NLB	0000				
ISSUE DATE	09-13-01				
SCALE					
NONE					