

EXISTING (FIRE STATION #2)

PANEL: A2			PANEL VOLTAGE: 240/120 1 Ø 3 W BUS: 225A MAINS: LO AIC RATING: 10,000 MOUNTING: FLUSH										CIRCUIT CODE: blank or N : NON-CONTINUOUS L : LONG-CONTINUOUS R : DEMANDABLE RECEPTACLES K : KITCHEN NO. OF EQUIPMENT: 0										
DATE: 07/05/01 TIME: 15:35:21 JOB: 01-082(2)																							
LOAD DESIGNATION			C O N N E C T E D V A										LOAD DESIGNATION										
NO	TRIP	POLE	DESCRIPTION	(NOTE)	M	R	L	ΦA	ΦB	A	B	ΦA	ΦB	L	R	M	(NOTE)	DESCRIPTION	TRIP	POLE	CODE	NO	
1			EXISTING LOAD					-	-			100	-	-			①	SMOKE DETECTORS	20	1	L	2	
3								-	-			-	-	-				EXISTING LOAD				4	
5								-	-			-	-	-								6	
7								-	-			-	-	-								8	
9								-	-			-	-	-								10	
11								-	-			-	-	-								12	
13								-	-			-	-	-								14	
15								-	-			-	-	-								16	
17								-	-			-	-	-								18	
19								-	-			-	-	-								20	
21								-	-			-	-	-								22	
23								-	-			-	-	-								24	
25	20	1	UH-1	①				500				3250	3250				③	RTU-1	50	2	L	26	
27			EXISTING LOAD					-	-			3250	-	-								28	
29	20	1	EC PUMP	①				100				1920	1920					EXHAUST FAN	30	1	L	30	
31			ROOF RECEPTS	①				540				1920	-	-								32	
33			EXISTING SPARE					-	-			-	-	-								34	
35								-	-			-	-	-								36	
37								-	-			-	-	-								38	
39								-	-			-	-	-								40	
41			EXISTING SPACE					-	-			-	-	-								42	
43	30	1	EC-1	②				1800				-	-	-					EXISTING SPACE				44
			PHASE TOTALS			ΦA:			ΦB:						TOTAL CONNECTED KVA								