

CAREY AVENUE
(PUBLIC)

CONCORD STREET
(PUBLIC)

LASALLE STREET
(PUBLIC)

MILLER AVENUE
(PUBLIC)

APN#
139-21-510-057

1012

1" PE RISER
2-FOOT MSA SPREAD
45 LF-1" SERVICE

MILLER AVENUE IS PAVED,
COMPLY WITH USD DWG NO.
503B & 500BT.

2" PVC, 71' MOP 43#

CONSTRUCTION NOTES

- SUGGESTED GAS LINE LOCATIONS ARE TO CLEAR SUBSTRUCTURES, LOCATE IN THE FIELD.
- ALL PIPELINE CONSTRUCTION WITHIN RIGHT-OF-WAY WILL CONFORM TO APPLICABLE JURISDICTIONAL SPECIFICATIONS.
- GAS MAINS SHALL BE PURGED PER OPERATIONS MANUAL.
- DO NOT SCALE THIS DRAWING.
- ANY CHANGES IN THE MAIN LOCATION MUST BE AUTHORIZED BY SWG INSPECTOR AND/OR ENGINEER.
- REQUEST FOR SURVEYING AND/OR STAKING WILL BE SUBMITTED TO ENGINEER 72 HOURS IN ADVANCE, MINIMUM.
- PAVEMENT RESTORATION AND BACKFILL TO COMPLY WITH RTC DRAWING NO'S. 500BT & 503B.

I REVIEWED THE PROCEDURES PERFORMED AND FOUND THEM,
ADEQUATE () INADEQUATE ()**

** INADEQUATE COMMENTS

SIGNATURE: DATE:

SIGNATURE: DATE:

Purge Plan was completed in accordance with the Operations Manual Guidelines by:

Name

Date

CUSTOMERS 1 CYCLE ROUTE AREA LV

SYSTEM D_VALLEY_WIDE

DR. NO. 21DR10002364

SEGMENT M.A.O.P. N/A

SYSTEM M.A.O.P. 43 psig

SYSTEM M.O.P. 43 psig

Call before you Dig

Avoid cutting underground utility lines. It's costly.

Call



OR
1-800-227-2600

AND
CLARK COUNTY TRAFFIC OPERATIONS
1-702-455-7544

NOTE:
THE INFORMATION SHOWN ON THIS PLAN IS BASED
ON PRELIMINARY RESEARCH WITHOUT TITLE REPORTS.

DESCRIPTION	BY	DATE	APPROV.
124353			
REVISIONS			
Southwest Gas Corporation			

MAIN			
SERVICE			
3800201	1" P.E.	45 LF	
UNIT NO.	UNIT TYPE	INSTL.	RET.
		PROPOSED	COMPLETED
PROPERTY UNITS			

AS-BUILT DRAWING-PRESSURE TEST DATA			
PIPE DIA.	TEST MEDIUM	TEST METHOD	
PIPE LENGTH	☐ AIR ☐ GAUGE		
PIPE TYPE	☐ NITROGEN ☐ CHART		
MIN. DURATION	☐ WATER ☐ GAUGE/PRESS REC SN#		
	☐ SOAP		
TEST PRES. (PSIG)	START	END	
TIME			
DATE			
PERFORMED BY			

VISUAL INSPECTION CERTIFICATION			
I HAVE VISUALLY INSPECTED ALL HEATED FUSIONS, SOLVENT CEMENT, MECHANICAL JOINTS, AND WELDS THAT I HAVE PERFORMED			
NAME	DATE		
AS-BUILTS ACCEPTED BY	DATE		
POSTED BY	DATE		
POSTING QCD BY	DATE		

CONSTRUCTION	
INSPECTOR	
FOREMAN	
REVIEWED BY	
PERMIT INFORMATION	
CITY OF LAS VEGAS	
TAX CODE	02-0200

ISOLATION AREA	W. R. NO.
083	1192436
LOCATION	TILE NO.
MILLER AVENUE CONCORD STREET	x624 y323
T=20S R=61E S=21	
#710-002TA	

ENGINEER/TECHNICIAN	DAVID F. RIEDLANDER	PHONE	365-2203
ACCOUNT REP.	SHANTE ANDERSON	PHONE	528-8596
PROJECT CONTACT	ROGER COOPER		917-4377
SHEET NO. 1 OF 1	SCALE 1"=30'	DATE	6-11-2010
DWN. BY RICK BERGIER	CHKD. BY	APPVD. BY	
TITLE			
1012 MILLER AVENUE			
107V5467			
MILLER AVENUE & CONCORD STREET			