

IRRIGATION NOTES

- REFER TO IRRIGATION DETAILS (SHEETS 11.01 & 11.02) AND SPECIFICATIONS FOR INSTALLATION PROCEDURES.
- SYSTEM HAS BEEN DESIGNED BASED ON A STATIC WATER PRESSURE OF 80 PSI AT THE PUMP.
- CONTRACTOR SHALL FIELD VERIFY PRESSURE AT PUMP LOCATION PRIOR TO ORDERING MATERIALS OR STARTING ANY IRRIGATION INSTALLATION AND NOTIFY CONSULTANT OF ANY DIFFERENCE FROM STATED PRESSURE. IF CONTRACTOR FAILS TO NOTIFY CONSULTANT HE ASSUMES FULL RESPONSIBILITY FOR ANY SYSTEM ALTERATIONS AS DIRECTED BY THE CONSULTANT.
- INSTALL BUSHNITZ SERIES PRESSURE COMPENSATING EMITTERS TO PLANT MATERIAL PER DETAILS 11.03, 11.04 AND THE FOLLOWING SCHEDULE:

PLANT SIZE	EMITTER NUMBER	QUANTITY
8 GAL SHRUB	BUSHNITZ BL210	2 EACH
24" BOX TREE	BUSHNITZ BL220	6 EACH
36" BOX TREE	BUSHNITZ BL220	6 EACH

EMITTERS ONLY ARE TO BE INSTALLED ABOVE GRADE AND ALL PIPING SHALL BE THOROUGHLY FLUSHED PRIOR TO EMITTER INSTALLATION AS PER DETAILS AND SPECIFICATIONS. CONTRACTOR IS RESPONSIBLE FOR ANY NECESSARY FLUSHING OF EMITTERS DUE TO CLOGGING FOR THE DURATION OF THE MAINTENANCE PERIOD AS OUTLINED IN THE LANDSCAPE SPECIFICATION. CONTRACTOR IS RESPONSIBLE FOR REPLACEMENT OF ANY PLANT MATERIAL WHICH DIES DURING THE MAINTENANCE PERIOD AS A RESULT OF EMITTER CLOGGING.

5. INSTALL RAIN BIRD U-SERIES PLASTIC NOZZLES ON ALL SPRAY HEADS. USE VARIABLE ARC NOZZLES WHERE NECESSARY TO PROVIDE HEAD TO HEAD COVERAGE AND PREVENT OVSERSPRAY ONTO PAVED SURFACE. INSTALL RAIN BIRD PCB PRESSURE COMPENSATING SCREENS ON ALL SPRAY HEADS SPACED 4 FEET AND LESS. REFER TO SCHEDULE IN RAIN BIRD CATALOG FOR APPROPRIATE SCREEN.

6. INSTALL IRRIGATION SLEEVES UNDER ALL PAVED SURFACES PER THE FOLLOWING SCHEDULE:

PIPE SIZE OR WIRE QUANTITY	REQUIRED SLEEVE(S)
3/4" LATERAL	1-3" SDR 35 PVC
1" LATERAL	1-3" SDR 35 PVC
1 1/4" LATERAL	1-3" SDR 35 PVC
1 1/2" LATERAL	1-4" SDR 35 PVC
2" LATERAL	1-4" SDR 35 PVC
2 1/2" LATERAL	1-4" SDR 35 PVC
3" LATERAL	1-6" SDR 35 PVC
1" PRESSURE SUPPLY LINE	1-3" SDR 35 PVC
1 1/4" PRESSURE SUPPLY LINE	1-4" SDR 35 PVC
1 1/2" PRESSURE SUPPLY LINE	1-4" SDR 35 PVC
2" PRESSURE SUPPLY LINE	1-6" SDR 35 PVC
2 1/2" PRESSURE SUPPLY LINE	1-6" SDR 35 PVC
3" PRESSURE SUPPLY LINE	1-8" SDR 35 PVC
4" PRESSURE SUPPLY LINE	1-8" SDR 35 PVC
1-20 CONTROL WIRES	1-3" SDR 35 PVC
2-40 CONTROL WIRES	2-2" SDR 35 PVC

IRRIGATION SCHEDULE

SYMBOL	MANUFACTURER	MODEL NUMBER	DESCRIPTION	DETAIL NUMBER
⊙ ⊙ ⊙	RAIN BIRD	1806-FR8 8 SERIES W/ NP COVER 9" GTR, HLF, FULL NOZZLE	8" POP-UP SPRAY HEAD (SEE NOTE 5)	1
⊙ ⊙ ⊙	RAIN BIRD	1806-FR8 8 SERIES W/ NP COVER 9" GTR, HLF, FULL NOZZLE	8" POP-UP SPRAY HEAD (SEE NOTE 5)	1
⊙ ⊙ ⊙	RAIN BIRD	1806-FR8 8 SERIES W/ NP COVER 10" GTR, HLF, FULL NOZZLE	8" POP-UP SPRAY HEAD (SEE NOTE 5)	1
⊙ ⊙ ⊙	RAIN BIRD	1806-FR8 8 SERIES W/ NP COVER 10" GTR, HLF, FULL NOZZLE	8" POP-UP SPRAY HEAD (SEE NOTE 5)	1
⊙ ⊙ ⊙	RAIN BIRD	1806-FR8 8 SERIES W/ NP COVER 10" GTR, HLF, FULL NOZZLE	8" POP-UP SPRAY HEAD (SEE NOTE 5)	1
⊙ ⊙ ⊙	RAIN BIRD	5505-55-NP-245	GEAR DRIVEN ROTOR (W/ 245 NOZZLE)	2
⊙ ⊙ ⊙	RAIN BIRD	5505-55-NP-2	GEAR DRIVEN ROTOR (W/ 2 NOZZLE)	2
⊙ ⊙ ⊙	RAIN BIRD	1005-55-NP-8	GEAR DRIVEN ROTOR (W/ 8 NOZZLE)	2
⊙ ⊙ ⊙	RAIN BIRD	1005-55-NP-10	GEAR DRIVEN ROTOR (W/ 10 NOZZLE)	2
⊙ ⊙ ⊙	RAIN BIRD	6504-PCFC-55-H8-8-P	GEAR DRIVEN ROTOR (W/ 8 NOZZLE)	2
⊙ ⊙ ⊙	RAIN BIRD	FEB SERIES	ELECTRIC CONTROL VALVE (SIZE PER PLAN)	3
⊙	PER DETAIL		1" DRIP VALVE ASSEMBLY	4
⊙	RAIN BIRD	44NP	QUICK COUPLING VALVE	5
⊙	RAIN BIRD	44NP	QUICK COUPLING VALVE W/ 1/2" ROUND CONCRETE VALVE BOX	14
⊙	APPROVED		GATE VALVE (LINE SIZE)	6 & 7
⊙	RAIN BIRD	ESF-5AT-20	FIELD SATELLITE UNIT (SEE PLAN)	11
⊙	RAIN BIRD	CCU-28-8	CLUSTER CONTROL UNIT	16
⊙	PER DETAIL		PUSH BUTTON DETAIL IS SHOWN AND IRRIGATION START DETAIL AT SH1.001	
⊙	APCO	50	AIR RELEASE VALVE	8
⊙	EXISTING		PRESSURE SUPPLY LINE	
---	APPROVED	8CH 40 BE PVC	PURPLE PRESSURE SUPPLY LINE UP TO 2 1/2" (SIZE PER PLAN)	
---	APPROVED	CL 200 RT PVC	PURPLE PRESSURE SUPPLY LINE 3" AND LARGER (SIZE PER PLAN)	
---	APPROVED	8CH 40 BE	PVC LATERAL LINE	
---	APPROVED	8CH 40 BE - 1/4"	DRIP PVC LATERAL (SHRUB) (SEE NOTE 14 FOR EMITTER)	
---	APPROVED	8CH 40 BE - 1/4"	DRIP PVC LATERAL (TREE) (SEE NOTE 14 FOR EMITTER)	
---	PER DETAIL		DRIP LINE BLOW-OUT STUD	10
---	APPROVED		PVC IRRIGATION SLEEVE (SEE NOTE 16)	
---			FIELD SATELLITE UNIT & STATION NO. GALLONS PER MINUTE	
---			PLANT TYPE	
---			ELECTRIC CONTROL VALVE SIZE	

IRRIGATION RECORD DRAWINGS

LATERAL PIPE SIZING IS INDICATED BY THE FOLLOWING SYMBOLS:

3/4" - I	1 1/2" - X
1" - II	2" - V
1 1/4" - III	2 1/2" - IV

