

GENERAL NOTES:

A	AMPERE(S)
ABV	ABOVE
A/C	AIR CONDITIONING
AL	ALUMINUM
AMP	AMPERE
ANN	ANNUNCIATOR
AUTO	AUTOMATIC
AWG	AMERICAN WIRE GAUGE
BC	BARE COPPER
BKBD	BACKBOARD
BLDG	BUILDING
CAB	CABINET
CKT BKR	CIRCUIT BREAKER
CLG	CEILING
C	CONDUIT
CU	COPPER
CW	COLD WATER
DN	DOWN
DPDT	DOUBLE POLE DOUBLE THROW
EF	EXHAUST FAN
ELEC	ELECTRIC
EM	EMERGENCY
EQUIP	EQUIPMENT
EXIST	EXISTING
4W	FOUR WIRE
F	FUSE
FUT	FUTURE
GFCI	GROUND FAULT CIRCUIT INTERRUPTER
GRD	GROUND
HP	HORSEPOWER
J-BOX	JUNCTION BOX
LTG	LIGHTING
MTR	MOTOR
NC	NORMALLY CLOSED
NEC	NATIONAL ELECTRICAL CODE
NO	NORMALLY OPEN
PNL	PANEL
RECEPT	RECEPTACLE
RM	ROOM
SPDT	SINGLE POLE DOUBLE THROW
STR	STARTER
SWBD	SWITCHBOARD
TEL	TELEPHONE
T-STAT	THERMOSTAT
XFMR	TRANSFORMER
V	VOLT(S)
W	WATT(S)
WP	WEATHERPROOF

NOTES:

1. DIMENSIONS INDICATED ARE TO CENTERLINE OF DEVICE OR OUTLET FROM FINISHED FLOOR OR FINISHED GRADE.
2. ALL SYMBOLS MAY NOT BE USED ON THIS PROJECT.

1. THE CONTRACTOR SHALL VISIT THE PROJECT SITE TO DETERMINE EXISTING CONDITIONS. NO EXTRAS WILL BE ALLOWED FOR FAILURE TO DO SO.
2. FURNISH ALL MATERIALS AND TEMPORARY LIGHTS AND WIRING REQUIRED DURING CONSTRUCTION OF THE PROJECT FOR ALL TRADES THAT REQUIRE POWER. COMPLY WITH OSHA AND NEC REQUIREMENTS.
3. DO NOT SCALE DRAWINGS. FIELD VERIFY EXACT EQUIPMENT LOCATIONS PRIOR TO BEGINNING WORK.
4. IN THE EVENT OF CONFLICTS BETWEEN THE DRAWINGS AND THE SPECIFICATIONS, CONTRACTOR SHALL BID THE BETTER QUALITY OR GREATER QUANTITY. APPROPRIATE ADJUSTMENT WILL BE MADE AFTER BID.
5. CONTRACTOR SHALL REFER TO THE PROJECT GENERAL, ARCHITECTURAL, MECHANICAL AND STRUCTURAL DRAWINGS FOR ADDITIONAL INFORMATION AND REQUIREMENTS FOR THIS PROJECT.
6. FINAL CONNECTIONS TO ALL EQUIPMENT SHALL BE PER MANUFACTURER'S APPROVED WIRING DIAGRAMS, DETAILS AND INSTRUCTIONS. IT SHALL BE THE CONTRACTORS RESPONSIBILITY TO VERIFY REQUIREMENTS AND PROVIDE MATERIALS AND EQUIPMENT COMPATABLE WITH EQUIPMENT ACTUALLY SUPPLIED.

PLANS APPROVED
ELECTRICAL
Building & Safety Dept.
City of Las Vegas, Nevada

DRM AUG 14 2007

Does Not Include Structural, Architectural,
Plumbing/Mechanical or Off-Site
Improvements. Make No Change
Without Approval. Plan Is
Not a Permit to Violate City Ordinance.

ELECTRICAL DRAWING INDEX

RR-EG1.01 ELECTRICAL LEGEND AND GENERAL NOTES
RR-EG1.02 ELECTRICAL DIAGRAMS, SCHEDULES AND IECC COMPLIANCE
RR-E1.01 ELECTRICAL POWER & LIGHTING PLANS

NRC
engineers, inc.
Electrical Engineering


3320 Wynn Road, Suite D
Las Vegas, Nevada 89102
(702)248-1592, Fax:(702)248-1593
NRC Project No. PDG0604



	REVISIONS								
	CONSULTANT								

C WOR

Lorenzi Park Renovation
Phase I
Restroom/Concession/Storage Building
ELECTRICAL LEGEND
AND GENERAL NOTES



OWNER: CITY OF LAS VEGAS
DEPARTMENT OF PUBLIC WORKS
ARCHITECTURAL SERVICES

400 EAST STEWART AVENUE
LAS VEGAS, NEVADA 89101
PHONE: (702) 229-5533
FAX: (702) 384-4844
TDD: (702) 386-9100

DRAWING:	JRE
FILE	RREG101
DATE	JUNE 25 2007
SCALE	NONE
BED NO:	07-15341.01
CLV DWG NO:	65019-47

RR-EG1.01

117533