


OWNER: CITY OF LAS VEGAS
DEPARTMENT OF PUBLIC WORKS
ARCHITECTURAL SERVICES

400 EAST STEWART AVENUE
LAS VEGAS, NEVADA 89101
PHONE: (702) 229-8535
FAX: (702) 384-8846
TDD: (702) 386-9108

11.09



NOTATION NOTES

- IRRIGATION DETAILS (SHEETS 11.01 & 11.02) AND SPECIFICATIONS FOR THE FOLLOWING PROCEDURE.
 - THESE PLANS HAVE BEEN DESIGNED BASED ON A STATIC WATER PRESSURE OF 80 PSI AT THE PUMP.
 - CONTRACTOR SHALL FIELD VERIFY PRESSURE AT PUMP INSTALLATION PRIOR TO ORDERING MATERIALS OR STARTING ANY IRRIGATION INSTALLATION AND NOTIFY CONSULTANT OF ANY DIFFERENCE FROM STATED PRESSURE. IF CONTRACTOR FAILS TO NOTIFY CONSULTANT HE ASSUMES FULL RESPONSIBILITY FOR ANY SYSTEM ALTERATIONS AS DIRECTED BY THE CONSULTANT.
 - INSTALL BOUSHMITH SERIES PRESSURE COMPENSATING EMITTERS TO PLANT MATERIAL PER DETAILS #1, #3, #5 AND THE FOLLOWING SCHEDULE:
- | PLANT SIZE | EMITTER NUMBER | QUANTITY |
|--------------|-----------------|----------|
| 8 GAL SHRUB | BOUSHMITH 8L210 | 2 EACH |
| 24" BOX TREE | BOUSHMITH 8L220 | 6 EACH |
| 36" BOX TREE | BOUSHMITH 8L220 | 6 EACH |
- EMITTERS ONLY ARE TO BE INSTALLED ABOVE GRADE AND ALL PIPING SHALL BE THOROUGHLY FLUSHED PRIOR TO EMITTER INSTALLATION AS PER DETAILS AND SPECIFICATIONS. CONTRACTOR IS RESPONSIBLE FOR ANY NECESSARY FLUSHING OF EMITTERS DUE TO CLOGGING FOR THE DURATION OF THE MAINTENANCE PERIOD AS OUTLINED IN THE LANDSCAPE SPECIFICATION. CONTRACTOR IS RESPONSIBLE FOR REPLACEMENT OF ANY PLANT MATERIAL WHICH DIES DURING THE MAINTENANCE PERIOD AS A RESULT OF EMITTER CLOGGING.
- INSTALL RAIN BIRD U-SERIES PLASTIC NOZZLES ON ALL SPRAY HEADS. USE VARIABLE ARC NOZZLES WHERE NECESSARY TO PROVIDE HEAD TO HEAD COVERAGE AND PREVENT OVERSPRAY ONTO PAVED SURFACE. INSTALL RAIN BIRD PC9 PRESSURE COMPENSATING SCREENS ON ALL SPRAY HEADS SPACED 4 FEET AND LESS. REFER TO SCHEDULE IN RAIN BIRD CATALOG FOR APPROPRIATE SCREEN.
 - INSTALL IRRIGATION SLEEVES UNDER ALL PAVED SURFACES PER THE FOLLOWING SCHEDULE:
- | PIPE SIZE OR WIRE QUANTITY | REQUIRED SLEEVES |
|-----------------------------|------------------|
| 3/4" LATERAL | 1-2" 8DR 35 PVC |
| 1" LATERAL | 1-2" 8DR 35 PVC |
| 1 1/4" LATERAL | 1-2" 8DR 35 PVC |
| 1 1/2" LATERAL | 1-4" 8DR 35 PVC |
| 2" LATERAL | 1-4" 8DR 35 PVC |
| 2 1/2" LATERAL | 1-6" 8DR 35 PVC |
| 3" LATERAL | 1-6" 8DR 35 PVC |
| 1" PRESSURE SUPPLY LINE | 1-2" 8DR 35 PVC |
| 1 1/4" PRESSURE SUPPLY LINE | 1-4" 8DR 35 PVC |
| 1 1/2" PRESSURE SUPPLY LINE | 1-4" 8DR 35 PVC |
| 2" PRESSURE SUPPLY LINE | 1-4" 8DR 35 PVC |
| 3" PRESSURE SUPPLY LINE | 1-6" 8DR 35 PVC |
| 4" PRESSURE SUPPLY LINE | 1-6" 8DR 35 PVC |
| 1-20 CONTROL WIRES | 1-2" 8DR 35 PVC |
| 2-40 CONTROL WIRES | 2-2" 8DR 35 PVC |

IRRIGATION SCHEDULE



SYMBOL	MANUFACTURER	MODEL NUMBER	DESCRIPTION	DETAIL NUMBER
○ ○ ○	RAIN BIRD	1806-PRS 5 SERIES W/ NP COVER 5' GTR. H.F.P. FULL NOZZLE	6" POP-UP SPRAY HEAD (SEE NOTE #5)	1
○ ○ ○	RAIN BIRD	1806-PRS 8 SERIES W/ NP COVER 8' GTR. H.F.P. FULL NOZZLE	6" POP-UP SPRAY HEAD (SEE NOTE #5)	1
○ ○ ○	RAIN BIRD	1806-PRS 12 SERIES W/ NP COVER 12' GTR. H.F.P. FULL NOZZLE	6" POP-UP SPRAY HEAD (SEE NOTE #5)	1
○ ○ ○	RAIN BIRD	1806-PRS 12 SERIES W/ NP COVER 12' GTR. H.F.P. FULL NOZZLE	6" POP-UP SPRAY HEAD (SEE NOTE #5)	1
○ ○ ○	RAIN BIRD	1806-PRS 15 SERIES W/ NP COVER 15' GTR. H.F.P. FULL NOZZLE	6" POP-UP SPRAY HEAD (SEE NOTE #5)	1
○ ○ ○	RAIN BIRD	5508-88-NP-268	GEAR DRIVEN ROTOR (W/ 268 NOZZLE)	2
○ ○ ○	RAIN BIRD	5508-88-NP-2	GEAR DRIVEN ROTOR (W/ 2 NOZZLE)	2
○ ○ ○	RAIN BIRD	7008-88-NP-8	GEAR DRIVEN ROTOR (W/ 8 NOZZLE)	2
○ ○ ○	RAIN BIRD	7008-88-NP-16	GEAR DRIVEN ROTOR (W/ 16 NOZZLE)	2
○ ○ ○	RAIN BIRD	6504-PC/RC-68-H8-B-P	GEAR DRIVEN ROTOR (W/ 8 NOZZLE)	2
○ ○ ○	RAIN BIRD	FE8 SERIES	ELECTRIC CONTROL VALVE (SIZE PER PLAN)	3
○ ○ ○	PER DETAIL		1" DRIP VALVE ASSEMBLY	4
○ ○ ○	RAIN BIRD	44NP	QUICK COUPLING VALVE	5
○ ○ ○	RAIN BIRD	44NP	QUICK COUPLING VALVE W/ 1/2" ROUND CONCRETE VALVE BOX	6 & 7
○ ○ ○	APPROVED	ESP-6AT-28	FIELD SATELLITE UNIT (SEE PLAN)	11
○ ○ ○	RAIN BIRD	CCU-28-6	CLUSTER CONTROL UNIT	16
○ ○ ○	MCCAIN TRAFFIC	1"PC27-ADA	PUSH BUTTON IRRIGATION START	18
○ ○ ○	APCO	950	AIR RELEASE VALVE	8
○ ○ ○	EXISTING		PRESSURE SUPPLY LINE TO BE REMOVED OR ABANDON	
○ ○ ○	EXISTING		PRESSURE SUPPLY LINE (PROTECT IN PLACE UNTIL NEW PRESSURE SUPPLY LINE IS INSTALLED AND CONNECTED TO PUMP STATION)	
○ ○ ○	APPROVED	8CH 40 BE PVC	PURPLE PRESSURE SUPPLY LINE UP TO 2 1/2" (SIZE PER PLAN)	
○ ○ ○	APPROVED	CL 100 RT PVC	PURPLE PRESSURE SUPPLY LINE 3" AND LARGER (SIZE PER PLAN)	15
○ ○ ○	APPROVED	8CH 40 BE	PVC LATERAL LINE	
○ ○ ○	APPROVED	8CH 40 BE - 3/4"	DRIP PVC LATERAL (SHRUB) (SEE NOTE #4 FOR EMITTER)	11
○ ○ ○	APPROVED	8CH 40 BE - 3/4"	DRIP PVC LATERAL (TREE) (SEE NOTE #4 FOR EMITTER)	12
○ ○ ○	PER DETAIL		DRIP LINE BLOW-OUT STUB	10
○ ○ ○	APPROVED		PVC IRRIGATION SLEEVE (SEE NOTE #6)	
○ ○ ○			FIELD SATELLITE UNIT # STATION NO.	
○ ○ ○			GALLONS PER MINUTE	
○ ○ ○			PLANT TYPE	
○ ○ ○			ELECTRIC CONTROL VALVE SIZE	

THESE PLANS ARE DIAGRAMMATIC, THEY DO NOT REPRESENT EXACT LOCATION OF IRRIGATION EQUIPMENT REFER TO SPECIFICATIONS AND DETAILS.

LATERAL PIPE SIZING IS INDICATED BY THE FOLLOWING SYMBOLS:
 3/4" - I 1 1/2" - X
 1" - II 2" - V
 1 1/2" - III 2 1/2" - IV

ADD ALTERNATE #1

IF ADD ALTERNATE #1 IS NOT INSTALLED, CONTRACTOR TO INSTALL APPROXIMATELY 24 RAIN BIRD 1008-88-NP-10 ROTORS AT 4' APART ALONG THE WALK ON THE EAST EDGE OF THE ADD ALTERNATE #1. THIS WILL REQUIRE A TEMPORARY 3" PRESSURE SUPPLY LINE, APPROXIMATELY 5' VALVES AND CONTROL WIRES AS NECESSARY. VALVES ARE NOT TO EXCEED 50 GPM PER ZONE. EXISTING HEADS WITHIN THE ADD ALTERNATE AREA THAT WERE DISABLED BY THE INSTALLATION OF THE NEW IRRIGATION SYSTEM, MUST BE RECONNECTED TO THE ALTERNATE AREA #1 TEMPORARY SYSTEM AS NECESSARY. IT MAY ALSO BE NECESSARY TO ADJUST THE ARC OF EXISTING HEAD TO PREVENT OVERSPRAY ONTO THE NEW WALK. THE TEMPORARY PRESSURE SUPPLY LINE AND VALVES SHALL BE INSTALLED ON THE WEST SIDE OF THE WALK WITHIN THE ADD ALTERNATE AREA.



CONNECT NEW PRESSURE SUPPLY LINE TO THE EXISTING 6" PRESSURE SUPPLY LINE AT THIS LOCATION

117469