





THE IRRIGATION SYSTEM IS DESIGNED HYDRAULICALLY TO ONLY OPERATE ONE (1) STATION / VALVE PER EACH CONTROLLER AT ANY ONE TIME. NO TWO (2) STATIONS / VALVES PER ANY ONE (1) CONTROLLER SHALL BE PROGRAMMED TO OPERATE AT THE SAME TIME, DUE TO HYDRAULICS OF THE PUMP AND THE IRRIGATION DESIGN.

NOTE:
THE LATERAL SIZE BETWEEN TWO IDENTICAL
TICK MARKS SHALL BE SIZED THE SAME.
MINIMUM PIPE SIZE IS 3/4"

CONTRACTOR SHALL INSTALL NEW MAINLINE AND REMOTE CONTROL VALVE (RCV) WIRES THAT WILL BE CONNECTED BACK TO CONTROLLER "3" & "4" TO THE EXISTING IRRIGATION IN THIS AREA. CONTRACTOR SHALL FIELD LOCATE THE EXISTING MAINLINE AND RCV LOCATIONS IN THIS AREA & CONNECT THE NEW MAINLINE AND RCV WIRES INTO THESE EXISTING RCV LOCATIONS.



 Call: TOLL FREE
1-800
227-2600

TWO WORKING DAYS BEFORE YOU DIG