



SHEET NOTES:

- ① NOT USED.
- ② NEMA 3R ENCLOSED 30A 1P. NON FUSED DISCONNECT SWITCH.
- ③ NEMA 3R ENCLOSED 60A 2P. FUSIBLE DISCONNECT SWITCH. FUSE AT 60A WITH FRN-R FUSE.
- ④ NOT USED
- ⑤ NEMA 3R ENCLOSED 30A 2P. FUSIBLE DISCONNECT SWITCH. FUSE AT 15A WITH FRN-R FUSES.
- ⑥ SAME AS NOTE ⑤ EXCEPT FUSE AT 20A.
- ⑦ NEMA 3R ENCLOSED NEMA 37 1/2 1P. 250V. 2P. MAGNETIC STARTER. PROVIDE 120V. CONTROL COIL. (2) N.C. (2) N.O. AUXIL. CONTACTS AND OIL PROTECTION.
- ⑧ AUTO FAN SHUTDOWN REQUIRED. FURNISH AND INSTALL DUCT MTD. SMOKE DETECTOR IN RETURN AIR PER U.M.C. 1009. INSTALL N.C. CONTACTS OF DETECTOR IN SERIES WITH UNIT CONTROL COIL.
- ⑨ COORDINATE LOCATION OF OUTLET WITH DESK LAYOUT.
- ⑩ COORDINATE LOCATION OF OUTLET WITH MICROWAVE.
- ⑪ MOUNT IN CABINET. COORDINATE LOCATION WITH EQUIPMENT IN CABINET.
- ⑫ RECEPTACLE MOUNTED ON ROOF PER U.M.C. 504.
- ⑬ MOUNT ADJACENT TO ANTENNA RACK ON ROOF.
- ⑭ NOT USED
- ⑮ SAME AS ② EXCEPT FUSE AT 3A.
- ⑯ SAME AS ⑤ EXCEPT FUSE AT 4A.
- ⑰ SAME AS ⑤ EXCEPT FUSE AT 7A.
- ⑱ 1/2" EC TO CONTROL CABINET. SEE SIGNAL PLAN.
- ⑲ COORDINATE EXACT LOCATION AND REQUIREMENTS WITH EQUIPMENT.
- ⑳ CONDUIT STUB IN CLG. SPACE FOR FUTURE ADDITION.
- ㉑ DOOR CHIME. MOUNT 6" BELOW CEILING.
- ㉒ EMERGENCY FUEL SHUTDOWN SWITCH. NEMA 3R ENCLOSED 30A 2P. NON-FUSED DISCONNECT SWITCH. PAINT RED AND MARK 'EMERGENCY PUMP OFF'.
- ㉓ PROVIDE J-BOX FOR DOOR LOCKING SYSTEM PUSHBUTTON.
- ㉔ FLUSH RECEPT IN CEILING FOR OWNER FURNISHED TRICKLE CHARGER AND REEL LIGHT. VERIFY LOCATION AND MOUNTING REQUIREMENTS PRIOR TO INSTALLATION.
- ㉕ STUB-UP FOR IRRIGATION CONTROLLER. VERIFY LOCATION PRIOR TO INSTALLATION.
- ㉖ CONNECT GENSET BLOCK HEATER & TRICKLE CHARGER AS REQUIRED.
- ㉗ 1/2" EC TO J-BOX ADJACENT TO PANELS.
- ㉘ ROUTED THRU 3-POSITION SWITCHES (ONE FOR @ OPERATOR) LOCATED AT ㉗
- ㉙ EMPTY CONDUIT FOR FUTURE (ABANDONED) DOOR CONTROL LOCATIONS

GENERAL NOTE:

REFER TO SHEET E-23 FOR EXHAUST FAN AND EVAP COOLER CONTROL.

⚠️ REVISED EMERGENCY POWER, ETC.

RECORD DRAWING

POWER PLAN - STATION NUMBER 2

SCALE: 1/8" = 1'-0"

AS-BUILT 12-15-89

RICHARDSON CONSTRUCTION, INC.

HARRIS ENGINEERS, INC. MECHANICAL/ELECTRICAL CONSULTANTS
 1100 WEST WASHINGTON AVENUE SUITE 1000 DENVER, CO 80202
 303-733-1100
 RICHARDSON CONSTRUCTION, INC. ENGINEERING/ARCHITECTURE
 1000 WEST WASHINGTON AVENUE SUITE 1000 DENVER, CO 80202
 303-733-1100
 SHEET 105
 LAS VEGAS FIRE DEPARTMENT
 CITY OF LAS VEGAS, NEVADA
 POWER PLAN - FIRE STATION #2