



SEE A M2.1 FOR THIS AREA

PROVIDE 1/2" X 1/2" X 1" EGGGRATE CORE RETURN CEILING IN ALCOVE - COORDINATE WITH ARCHITECT (TYP FOR 2)  
 60/24 INTERNALLY LINED RETURN DUCT (IDE FOR 2)  
 60/24 TO FULL OPENING SIZE RA FLENUM (TYP FOR 2)  
 SEAL RA FLENUM TO WALLS (TYP)

OPEN END RETURN W/ DISCHARGE GRILLE ON SUPPLY SIDE

- ### SHEET NOTES
- ① NOT USED.
  - ② SEE 8/M4.2 (TYPICAL).
  - ③ SEE 3/M4.2 (TYPICAL).
  - ④ SEE 1/M4.2 (TYPICAL).
  - ⑤ SEE 2/M4.2.
  - ⑥ KEEP AREA FREE OF DUCTWORK AND PIPING.
  - ⑦ W/FACTORY INSTALLED CEILING FIRE DAMPER.

- ### GENERAL NOTES
1. ALL TRADES TO INSURE THAT SUFFICIENT SPACE IS PROVIDED FOR FILTER AND UNIT MAINTENANCE.
  2. PROTECT ALL OPENINGS THRU CEILING WITH FIRE RATED DAMPERS PER UL DESIGN NO. F225 AND F809 AS INDICATED ON THE ARCH. DRAWINGS. DAMPER ASSEMBLY SHALL BE UL LISTED AND COMPATIBLE WITH ITS ASSOCIATED ASSEMBLY. FIELD VERIFY ALL LOCATIONS AND METHODS.

HVAC FLOOR PLAN - AREA B

SCALE: 1/8" = 1'-0" M2.1

REVISION	DESCRIPTION	DATE	REV. BY

1525 WEST OAKY BLVD  
 LAS VEGAS, NV 89102  
 (702) 383-0077  
 FAX 383-0057

WAYNE SCHREINER AIA  
 THOMAS M. SILVA AIA

Sheet Title	HVAC PLAN - AREA B
Job Title	CITY OF LAS VEGAS DEPARTMENT OF PARK AND LEISURE ACTIVITIES THE ARBORS COMMUNITY CENTER @ SUMMERLIN
Job	961001
Date	2-20-98
Drawn By	DGD
Check	KJK
Sheet	M2.1
	671-48
Of	3 of 10

**DUNHAM ASSOCIATES**  
 MECHANICAL ELECTRICAL  
 CONSULTING ENGINEERS

3034 Regal Avenue  
 Las Vegas, NV 89102  
 Ph. (702) 223-9677  
 Fax. (702) 223-9920