

VICINITY MAP

1. ALL CONSTRUCTION AND MATERIALS SHALL BE IN ACCORDANCE WITH LATEST EDITION OF THE DESIGN AND CONSTRUCTION STANDARDS FOR WASTEWATER COLLECTION SYSTEMS AND THE UNIFORM SPECIFICATIONS FOR PUBLIC WORKS AND CIVIL IMPROVEMENTS, CLARK COUNTY AREA, NEVADA, AS AMENDED. IT WILL BE THE RESPONSIBILITY OF THE CONTRACTOR TO BE AWARE OF THE CONTENTS OF THE ABOVE SPECIFICATIONS.
2. IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO PERFORM CONSTRUCTION AS PER PLANS. ANY ADDITIONS, DELETIONS, OR CHANGES SHALL FIRST MEET WITH THE APPROVAL OF THE CITY ENGINEER.
3. CHSEL "3" OR "6" IN CURBS WHERE SEWER OR GAS LATERALS PASS UNDER THE CURB.
4. POLYVINYL (PVC) SEWER PIPE SHALL MEET ASTM D-3034 SDR 35 SPECIFICATIONS, INSTALLED WITH SAND BEDDING AND BACKFILL OF PIPE II AGGREGATE BASK.
5. ALL MANHOLES PAVED IN STREETS EIGHTY (80') FOOT OR LARGER SHALL HAVE CONCRETE COLLARS. STREETS LESS THAN EIGHTY (80') FOOT WILL REQUIRE RETROFIT IF PAVING DOES NOT CONFORM TO CITY STANDARDS AT THE MANHOLE.
6. THE SADDLES SHALL BE USED TO CONNECT SEWER LATERALS TO EXISTING MAIN LINES UP TO TWELVE INCH (12") DIAMETER. CONNECTIONS TO FIFTEEN INCH (15") OR LARGER MAINS SHALL REQUIRE SPECIAL PROCEDURES. IN LINE JOINTS SHALL BE USED ON TWELVE INCH (12") OR ABOVE.
7. WATER MAINS SHALL BE PROTECTED IN ACCORDANCE WITH LVWD STANDARDS WHENEVER A SEWER MAIN CROSSES OVER A WATER MAIN OR THE SEWER IS LESS THAN EIGHTEEN INCHES (18") UNDER A WATER MAIN.
8. THE CONTRACTORS INSTALLING SEWER MAINS THAT WILL BE UNDER THE JURISDICTION OF THE CITY OF LAS VEGAS SHALL BE UNDER THE CITY OF LAS VEGAS.
9. ALL CITY OF LAS VEGAS WILL NOT ACCEPT ANY SEWER MAINS WHICH HAVE A VERTICAL DEFLECTION OF MORE THAN ONE TENTH (0.1) OF A FOOT FROM THE APPROVED CONSTRUCTION PLANS AT ANY LOCATION. SEWER MAINS FOUND TO EXCEED THIS TOLERANCE WILL HAVE TO BE REPAIRED OR REMOVED AND REPLACED TO THE SATISFACTION OF THE CITY ENGINEER PRIOR TO THE START OF THE NEXT CONSTRUCTION PHASE.
10. INSTALLATION OF CURBED SEWER REQUIRES THE USE OF C-300 PVC PIPE WHICH ALLOWS FOR PIPE DEFLECTION AT THE JOINTS.

CLARK COUNTY FIRE DEPARTMENT NOTES

DEPARTMENT APPROVAL
Mike Robinson 10/6/05
APPROVAL OF THESE PLANS SHALL NOT BE CONSIDERED
A PERMIT FOR, OR AN APPROVAL OF,
VIOLATION OF ANY OF THE PROVISIONS OF THE
CITY OR COUNTY LAWS. FIRE FLOW 2,500 GPM AT
S.I. RESIDUAL

CLARK COUNTY FIRE
DEPARTMENT APPROVAL

BY *Donna Robinson* *10/6/05*

APPROVAL OF THESE PLANS SHALL NOT BE CONSTRUED
TO BE A PERMIT FOR, OR AN APPROVAL OF,
ANY VIOLATION OF ANY OF THE PROVISIONS OF THE
STATE OR COUNTY LAWS. FIRE FLOW 2,500 GPM AT
20 P.S.I. RESIDUAL

HTE: 05-23250