

MATCH LINE "SR" 7+00 SEE ABOVE RIGHT



- (40) RELOCATE EXISTING 250 WATT HPS STREET LIGHT ASSEMBLY
- (41) 1-1/4" STREET LIGHT CONDUIT WITH WIRE. (C.L.V.)
- (42) CONNECT TO EXISTING STREET LIGHT CONDUIT
- (43) INSTALL NEW NO. 3 1/2 PULL BOX
- (44) CONSTRUCT 250 WATT HPS STREET LIGHT ASSEMBLY AND FOUNDATION
- (45) EXISTING NO. 7 PULL BOX
- (46) EXISTING 200 AMP SERVICE PEDESTAL
- (47) INSTALL NEW 200 AMP SERVICE PEDESTAL
- (48) COIL ADDITIONAL WIRE IN PULL BOX FOR FUTURE USE
- (61) INSTALL INTERCONNECT CABLE IN EXISTING CONDUIT
- (62) CONNECT TO EXISTING INTERCONNECT CONDUIT
- (63) INSTALL NEW DOUBLE STACKED NO. 7 PULL BOX
- (64) INSTALL NEW 3" INTERCONNECT CONDUIT WITH INTERCONNECT CABLE
- (65) INSTALL NEW 3" INTERCONNECT CONDUIT

	* RELOCATION OF EXISTING STREET LIGHTS FOR BOTH CIRCUITS A-1 AND A-2 WITH NO INCREASE IN LOAD TO EXISTING LIGHTING CIRCUIT.	
--	---	--

4450 W. SAHARA AVE., SUITE 150
LAS VEGAS, NEVADA 89102-1846
PHONE: (702) 870-2130
FAX: (702) 870-1731

RAINBOW BOULEVARD
SILVERSTREAM AVE. TO SMOKE RANCH ROAD
STREET LIGHT & INTERCONNECT PLAN
"SR" 1+00 TO "SR" 17+00

DRAWING NO.
107-V3519



SEE SHEET SL-6



UNDERGROUND SERVICE (USA)
AND
CLARK COUNTY TRAFFIC MANAGEMENT
OPERATIONS UNIT (702) 455-7544

