188.00 LF 21" PIPE 1350-D RCP OR VCP

660.00 LF 21" PIPE 1350 D RCP OR VCP

42.00 LF 21" PIPE 1350 D RCP OR VCP

APPROX. EXIST. ⊄ GRADE

10" VCP STUB & PLUG (8/48)

21" PIPE 90.00' @ 0.0231

21" PIPE 665.00' @ 0.0231

21" PIPE 45.00' @ 0.0231

TYPE "D" (3/50) 297+10.00 M.H. #S0.57

290+45.00 M.H. #S0.56

TYPE "D" (3/50)

PROFILE

SCALE: HORIZ. 1" = 30'
VERT. 1" = 6'

PIONEER WAY

FUTURE STREET

MONTECRISTO WAY

5 L.F. 10" VCP STUB & PLUG

21" PIPE

S.87° 52' 25" W.

℄ STREET & SURVEY LINE

MATCH LINE - SEE SHEET #37

MATCH LINE - SEE SHEET #35

BENCH MARK 203.0
STA. 203+04 - 48' RT. ⊄
ELY BOLT ON FIRE HYDRANT
NORTH SIDE SAHARA AVE.
C.L.V. DATUM
ELEV. 2470.21

NORTH
SCALE 1" = 30'

SAHARA AVENUE

AS BUILT DRAWING

JOB NO. 412.140

9/78 DIETERICH-POST 65328

REV	DATE	DESCRIPTION
1	1/10/85	"AS BUILT" - NO REVISIONS

R.E. NO. 7/20/85 DATE

REGISTERED PROFESSIONAL ENGINEER STATE OF NEVADA MICHAEL D. ROSS CIVIL

G. C. WALLACE
Consulting Engineers, Inc.
1100 East Sahara Ave. • Las Vegas, Nevada 89104 • 732-3330

Department of Public Services
SAHARA - OAKEY SEWER INTERCEPTOR
PLAN & PROFILE 290+00 TO 299+00

SHEET 36 OF 65 SHEETS

307-V 563 22-1-12