

BENCHMARK
 CITY OF LAS VEGAS BENCHMARK No. 7LV09 34C4
 A RIVET AND PLATE IN THE TOP OF CURB AT THE
 NORTHEAST CORNER OF PASEO BREEZE DRIVE AND DESERT MOON
 DR.
 ELEVATION=997.024 METERS (NAVD'88)
 ELEVATION=3271.07 US SURVEY FEET (NAVD'88)

BASIS OF BEARINGS
 SOUTH 83°00'00\"/>

DISCLAIMER NOTE:
 UTILITY LOCATIONS SHOWN HEREON ARE
 APPROXIMATE ONLY. IT SHALL BE THE
 CONTRACTOR'S RESPONSIBILITY TO DETERMINE THE
 EXACT HORIZONTAL AND VERTICAL LOCATION OF ALL
 EXISTING UNDERGROUND OR OVERHEAD UTILITIES
 PRIOR TO COMMENCING CONSTRUCTION. NO
 REPRESENTATION IS MADE THAT ALL EXISTING
 UTILITIES ARE SHOWN HEREON. THE ENGINEER
 ASSUMES NO RESPONSIBILITY FOR UTILITIES NOT
 SHOWN OR UTILITIES NOT SHOWN IN THEIR PROPER
 LOCATION. CONTRACTOR TO NOTIFY ENGINEER OF
 ANY CHANGES OR DISCREPANCIES.

Avoid overhead power line
 contact. It's costly.
**Call
 before you
 Overhead**
 1-702-227-2929
 Nevada Power
 Environment and Safety
 Services Department

Call before you Dig
 Avoid cutting underground
 utility lines. It's costly.
**Call
 811**
 1-800-227-2600
 CLARK COUNTY PUBLIC OPERATIONS
 1-702-455-7544

SEWER MANHOLE TABLE			
MH ID	TMH:	INV. IN:	INV. OUT:
SSMH #1	3358.3±		3350.38 (S)
SSMH #2	3353.1±	3346.01 (N)	3345.81 (S)
SSMH #3	3345.9±	3336.50 (N)	3336.30 (E)
SSMH #4	3343.8±	3335.60 (W)	3335.40 (E)
SSMH #5	3339.8±	3331.25 (N,W)	3331.05 (E)
SSMH #6	3336.3±	3326.00 (W)	3325.80 (E)
SSMH #7	3334.2±	3322.81 (W)	3322.61 (E)
SSMH #8	3332.8±	3321.60 (N,W)	3321.40 (S)
SSMH #9	3332.3±	3321.00 (N)	3320.80 (S)
SSMH #10	3326.8±	3317.00 (E,W)	3316.80 (S)
SSMH #11	3320.8±	3313.00 (N)	3312.80 (S)
SSMH #12	3315.6±	3304.15 (N,S)	3303.95 (E)
SSMH #13	3315.1±	3302.55 (W)	3302.35 (E)
SSMH #14	3352.2±		3343.45 (S)
SSMH #15	3341.6±	3334.39 (N)	3334.19 (S)
SSMH #16	3337.0±		3329.84 (S)
SSMH #17	3336.3±	3329.34 (N)	3329.14 (S)
SSMH #18	3330.8±		3323.52 (E)
SSMH #19	3315.8±	3304.80 (S)	3304.60 (N)
SSMH #20	3316.4±	3308.57 (E)	3308.37 (N)
SSMH #21	3317.7±	3310.02 (W)	3309.82 (E)
SSMH #22	3318.5±		3311.00 (E)

CITY OF LAS VEGAS FIRE DEPARTMENT APPROVAL

[Signature] 4/17/13
 DATE

APPROVAL OF THESE PLANS SHALL NOT BE CONSTRUED TO BE A PERMIT FOR,
 OR ANY APPROVAL OF, ANY VIOLATION OF ANY OF THE PROVISIONS OF THE
 STATE OR COUNTY LAWS.

FIRE FLOW 1,750 GPM AT 20 PSI RESIDUAL

APPROVED FOR CONSTRUCTION

[Signature]
 LAS VEGAS VALLEY WATER DISTRICT ENGINEERING SERVICES MANAGER
 DATE: 4/22/13 PROJECT# 121254

LVVWD APPROVED FIRE FLOW 1,750 GPM AT 20 PSI RESIDUAL

DATE	BY	APPD	DESCRIPTION
APRIL 17, 2013			
REV			


TOLL BROTHERS INC.
 1140 TOWN CENTER DRIVE SUITE 250
 LAS VEGAS, NV 89144
 PHONE: 702-243-9800 FAX: 702-243-9810

RCI Engineering
 3321 South Highland Drive, Suite 810, Las Vegas, NV 89109
 PHONE: 702-453-0800 FAX: 702-453-0801

IMPROVEMENT PLANS FOR
SANTALUZ AT SUMMERLIN VILLAGE 23A
 PARCELS ES-1 AND WS-1

OVERALL COMPREHENSIVE MASTER UTILITY PLAN
 CITY OF LAS VEGAS

NEVADA



4/17/2013
 DRAWING
MU-1
 SHIT 24 OF 39
 CLY DRAWING NUMBER
 10714284
 CLY PROJECT NUMBER 48157

1685
 Plan