



1. NO STONES OR LUMPS GREATER THAN 3" PERMITTED IN TRENCH 2' OR LESS IN WIDTH.
2. TRENCH WIDTH, BEDDING, SUBGRADE AND PIPE ZONE REQUIREMENTS FOR UTILITY INSTALLATIONS SHALL CONFORM TO THE RESPECTIVE UTILITY REQUIREMENTS.
3. CRUSHED ROCK MAY BE USED FOR PIPE BEDDING ONLY IF MATERIAL USE HAS BEEN SPECIFICALLY APPROVED BY THE GOVERNING AGENCY. SEE STANDARD DRAWING NO. 505 FOR PIPE BEDDING METHODS.
4. LAS VEGAS VALLEY WATER DISTRICT REQUIRES PIPE BEDDING AND BACKFILL WITHIN THE PIPE ZONE TO BE OF THE SAME MATERIAL.



AS-BUILT DRAWING-PRESSURE TEST DATA

		TEST MEDIUM	TEST METHOD
PIPE DIA. _____		☐ AIR	☐ GAUGE
PIPE LENGTH _____		☐ NITROGEN	☐ CHART
PIPE TYPE _____		☐ WATER	☐ GAUGE/
MIN. DURATION _____		☐ SOAP	PRESS REC SN# _____
TEST PRES. (PSIG) _____	START	END	
TIME _____	_____	_____	
DATE _____	_____	_____	
PERFORMED BY _____	_____	_____	

SYSTEM	D N VALLEY CENW
DR. NO.	21DR10002566
SEGMENT M.A.O.P.	N/A
SYSTEM M.A.O.P.	60 psig
SYSTEM M.O.P.	55 psig

PURGE PLAN WAS COMPLETED IN ACCORDANCE
WITH THE OPERATIONS MANUAL GUIDELINES BY:

PRINT: _____ DATE: _____
SIGNATURE: _____

[illegible]