



Date: October 22, 1999

Drawn By: DDT

Sheet Number:

NOTE:
REFER TO SITE PLAN, SHEET A101, FOR POOL DECK EXITING



SCALE: 3/16" = 1'-0"

PAGE 4 OF 5

[illegible]

USG Candy Shalt Wall for Two-Sided Structural Metalwork or Horizontal Sheet Shalt Protection

On Underlayment Laboratory, Inc. label data sheets, L1 design (USG Candy Shalt No R-131) and identified the panels as USG Type 1L-X (small flares three-sides).

VI. EVIDENCE SUBMITTED

Results of fire-resistance tests conducted in accordance with ASTM E-119:

VII. CONFORMANCE OR USE

The National Evaluation Service Committee finds that, in their entirety, the USG Candy Shalt Protection System described by the report are alternatives to fire-rated construction specified in the 1990 IFBC, American Building Code, the 1990 Standard Building Code with 1990/1996 Amendments, and the 1989 Uniform Building Code with 1989 Amendments/Supplements, subject to the following conditions:

1. This report does not include structural evaluation of the pendents below.
2. All cut openings and horizontal joints in metal-framed shaft enclosures with cardboard cores must be sealed with metal flashing.
3. Systems C and above are limited to use on corridor walls and on the horizontal enclosure on the underside of stairs (L1 "Cafe Stairs").
4. Assembly described in paragraph 11 may be used to protect two-hour horizontal shafts (horizontal duct shafts) or where a two-hour structural membrane is required, need is not part of a fire-rating or fire-resistance assembly. This system is designed to support its own dead weight plus and should not be used where there is an attic or loft above, or any probability of abuse.

This report is subject to re-examination in 12 years.

USE THIS ASSEMBLY

PLANS APPROVED
ARCHITECTURAL
Building & Trades Dept.
City of Las Vegas, Nevada

JCC DEC 03 2001

Does Not Include Structural, Electrical,
Plumbing/Mechanical or Civil Site
Improvements Made No Change
Without Approval Plan Is
Not a Permit to Violate Any Ordinance

APPROVAL IS FOR CLOUDED
AREAS OR LATEST REVISIONS
ONLY. SEE ORIGINALS FOR
OTHER REQUIREMENTS.

*SEE ATTACHED
DOCUMENTS
AND
REQUIREMENTS

***SEE ATTACHED
DOCUMENTS
AND
REQUIREMENTS**

8 3 8 7 0 2 3

CITY OF LAS VEGAS

SCALE: NONE

SCALE: NONE

SCALE: NONE

SCALE: NONE

4