



VICINITY MAP
NTS

- CONSTRUCTION NOTES:**
1. Gas Mains shall be purged per operations manual.
 2. All pipeline construction shall conform to applicable jurisdiction specifications.
 3. Do not scale this drawing.
 4. Service(s) to be 2"PE unless otherwise noted.
 5. Riser & Meter(s) at this location.

Purge Plan was completed in accordance with the Operations Manual Guidelines by:

Name _____ Date _____

Total footage located in Public RoW 165' +/-

APPROVALS:
[Signature] 12/10/03
CITY OF LAS VEGAS DATE

| LEGEND | |
|--------|-------------------|
| | Proposed gas main |
| | Existing gas main |

CALL BEFORE YOU DIG
CAN YOU DIG IT!
1-800-227-2600
(48Hrs. Advance Notice Required)

CUSTOMERS 1 CYCLE _____ ROUTE _____ AREA 35 LV 21

| | | | | | | | | | | | | | | |
|--|----|---------|---|------|----------|--|--|--|--|---|---|--|-------------------------|--|
| CHANGED ENTITY ADDED 12' PERMANENT PATCH. | DF | 10-6-03 | 3760102 | 2"PE | 345' +/- | | | | AS-BUILT DRAWING-PRESSURE TEST DATA PIPE DIA. _____ TEST MEDIUM _____ TEST METHOD _____ PIPE LENGTH _____ <input type="checkbox"/> AIR <input type="checkbox"/> GAUGE PIPE TYPE _____ <input type="checkbox"/> NITROGEN <input type="checkbox"/> CHART <input type="checkbox"/> WATER <input type="checkbox"/> GAUGE/PRESS REC SH <input type="checkbox"/> SOAP MIN. DURATION _____ START _____ END _____ TEST PRES. (PSIG) _____ TIME _____ DATE _____ PERFORMED BY _____ | VISUAL INSPECTION CERTIFICATION I HAVE VISUALLY INSPECTED ALL HEATED FUSIONS, SOLVENT CEMENT, MECHANICAL JOINTS, AND WELDS THAT I HAVE PERFORMED. NAME _____ DATE _____ | CONSTRUCTION INSPECTOR _____ FOREMAN _____ REVIEWED BY _____ | ISOLATION AREA 10 LOCATION ATLAS #/TITLE * | W. R. NO. 0306662889 | ENGINEER/TECHNICIAN D. FRIEDLANDER PHONE 365-2203 ACCOUNT REP. JOHN WRIGHT PHONE 365-2309 PROJECT CONTACT EMMIT 702-234-1017 SHEET NO. 1 OF 1 SCALE 1" = 30' DATE 7/21/03 OWN. BY R. SKROVE CHKD. BY _____ APPVD. BY _____ |
| | DF | 12-8-03 | 3800102 | 2"PE | 55' +/- | | | | | | | | | |
| REVISIONS NO. DESCRIPTION BY DATE APPVD. | | | PROPERTY UNITS UNIT NO. UNIT TYPE INSTL. RET. INSTL. RET. PROPOSED COMPLETED | | | | | | | | | | | |



10703679-SW6