SOUTHWEST GAS CORPORATION

F-CLV-VEGAS DRIVE 4" HP LOWERING
AT VEGAS/DECATUR
CITY OF LAS VEGAS, NV
WR# 1907825



NOTES:

1. NO STONES OR LUMPS GREATER THAN 3" PERMITTED IN TRENCH 2' OR LESS IN WIDTH.
2. TRENCH WIDTH, BEDDING, SUBGRADE AND PIPE ZONE REQUIREMENTS FOR UTILITY INSTALLATIONS SHALL CONFORM TO THE RESPECTIVE ENTITY REQUIREMENTS.
3. CRUSHED ROCK MAY BE USED FOR PIPE BEDDING ONLY IF MATERIAL USE HAS BEEN SPECIFICALLY APPROVED BY THE GOVERNING AGENCY. SEE STANDARD DRAWING NO. 505 FOR PIPE BEDDING METHODS.
4. LAS VEGAS VALLEY WATER DISTRICT REQUIRES PIPE BEDDING AND BACKFILL WITHIN THE PIPE ZONE TO BE OF THE SAME MATERIAL.

RTC STD DWG 503



LOCATION MAP
N.T.S.

LEGEND:

- EXISTING GAS LINE
- GAS LINE TO BE ABANDONED
- EXISTING GAS SERVICE
- PROPOSED MAIN GAS LINE (NEW)
- PROPOSED SERVICE LATERAL (NEW)
- PROPOSED SERVICE LINE (NEW)
- RIGHT OF WAY LINE
- STREET CENTERLINE
- PROPERTY LINE
- BACK OF CURB
- MATCHLINE
- EASEMENT
- EXISTING ANODELESS RISER
- EXISTING ANODE RISER
- EXISTING GAS LIGHT
- EXISTING GAS VALVE

SHEET INDEX

1. COVER SHEET
2. STEEL MATERIALS AND SIGNATURE SHEET
3. DESIGN PLAN
4. DETAIL SHEET
5. STRENGTH TEST REPORT AND TESTING DETAIL

53749 10014993-GAS

CPM Utility Plan Approval
CPM Project Name Vegas Drive Improvements
CPM Hansen # 11554 Date 4/16/14
CPM Project Manager Lorrie Lunert Dunford x6738
Approved by Lorrie Lunert

TOTAL FOOTAGE LOCATED IN CLV R/W 349'

APPROVED FOR CONSTRUCTION

THIS APPROVAL IS FOR WORK IN CLV R/W OR CLV EASEMENTS ONLY. OBTAINING PERMISSIONS OR EASEMENTS FOR WORK SHOWN ON PRIVATE PROPERTY IS THE RESPONSIBILITY OF THE UTILITY.

APPROVAL DATE

Hansen _____ Dwg _____

811 Know what's **below.** **Call** before you dig.

NO.	DESCRIPTION	BY	DATE	APPVD.
1.				
2.				
3.				
4.				

REVISIONS

SOUTHWEST GAS CORPORATION

TAX CODES	UNIT NO.	UNIT TYPE	INSTL. (PROPOSED)	RETIRED (PROPOSED)	INSTL. (COMPLETED)	RETIRED (COMPLETED)
SEE SHEET 2						

PROPERTY UNITS

AS-BUILT DRAWING-PRESSURE TEST DATA (SEE SHEET 2)

PIPE DIA. _____ TEST MEDIUM: ☐ AIR ☐ NITROGEN ☐ WATER ☐ DEQAP
PIPE LENGTH _____ TEST METHOD: ☐ GAUGE ☐ CHART ☐ GAUGE/PRESS REC SN#
PIPE TYPE _____
MIN. DURATION _____
TEST PRES. (PSIG) _____ START _____ END _____
TIME _____ _____
DATE _____ _____
PERFORMED BY _____ _____

VISUAL INSPECTION CERTIFICATION (SEE SHEET 2)

I HAVE VISUALLY INSPECTED ALL HEATED FUSIONS, SOLVENT CEMENT, MECHANICAL JOINTS, AND WELDS THAT I HAVE PERFORMED
NAME _____ DATE _____

AS-BUILTS ACCEPTED BY _____ DATE _____
POSTED BY _____ DATE _____
POSTING QC'D BY _____ DATE _____

CONSTRUCTION (SEE SHEET 2)

INSPECTOR _____
FOREMAN _____
REVIEWED BY _____

PERMIT INFORMATION
CITY OF LAS VEGAS
TAX CODE 02-0207

ISOLATION AREA	W.R. NO.
120-22	1907825
LOCATION	ATLAS #/TILE #
T20S R60E SEC 24 M.D.M.	x609y522

ENGINEER/TECH: MAX HUGHES		PHONE: 702-365-2022
ACCOUNT REP:		PHONE:
PROJECT CONTACT: MAX HUGHES		PHONE: 702-365-2022
SHEET NO: 1 OF 5	SCALE: N.T.S.	DATE: 4/15/14
DWN. BY: ZONE ENG	CHKD. BY:	APPVD. BY:

TITLE

F-CLV-VEGAS DRIVE 4" HP LOWERING AT VEGAS/DECATUR