

CPM Utility Plan Approval

CPM Project Name Vegetative Improvements

CPM Hansen # 11554 Date 5/15/14

CPM Project Manager Herb Linnert Dunsford x6738

Approved by: [Signature]

	EXISTING GAS LINE
	GAS LINE TO BE ABANDONED
	EXISTING GAS SERVICE
	PROPOSED MAIN GAS LINE (NEW)
	PROPOSED SERVICE LATERAL (NEW)
	PROPOSED SERVICE LINE (NEW)
	RIGHT OF WAY LINE
	STREET CENTERLINE
	PROPERTY LINE
	BACK OF CURB
	MATCHLINE
	EASEMENT
	EXISTING ANODELESS RISER
	EXISTING ANODE RISER
	EXISTING GAS LIGHT
	EXISTING GAS VALVE

1. COVER SHEET
2. STEEL MATERIALS AND SIGNATURE SHEET
3. DESIGN PLAN
4. DETAIL SHEET
5. STRENGTH TEST REPORT AND TESTING DETAIL

By: _____ Date: _____

Total footage located in Public ROW 26'

TOTAL FOOTAGE LOCATED IN
CLV R/W **204'**

THIS APPROVAL IS FOR WORK IN CLV R/W
OR CLV EASEMENTS ONLY. OBTAINING PERMISSIONS
OR EASEMENTS FOR WORK SHOWN ON PRIVATE
PROPERTY IS THE RESPONSIBILITY OF THE
UTILITY.

APPROVAL _____ DATE _____

Hansen _____ Dwg _____


ENGINEER/TECH: MAX HUGHES		PHONE: 702-365-2022
ACCOUNT REP:		PHONE:
PROJECT CONTACT: MAX HUGHES		PHONE: 702-365-2022
SHEET NO: 1 OF 5	SCALE: N.T.S.	DATE: 5/2/14
DWN. BY: ZONE ENG	CHKD. BY:	APPVD. BY:

F-CLV-VEGAS DRIVE 4" HP
DROP SECTION WEST OF MICHAEL



1. NO STONES OR LUMPS GREATER THAN 3" PERMITTED IN TRENCH 2' OR LESS IN WIDTH.
2. TRENCH WIDTH, BEDDING, SUBGRADE AND PIPE ZONE REQUIREMENTS FOR UTILITY INSTALLATIONS SHALL CONFORM TO THE RESPECTIVE ENTITY REQUIREMENTS.
3. CRUSHED ROCK MAY BE USED FOR PIPE BEDDING ONLY IF MATERIAL USE HAS BEEN SPECIALLY APPROVED BY THE GOVERNING AGENCY. SEE STANDARD DRAWING NO. 505 FOR PIPE BEDDING METHODS.
4. LAS VEGAS VALLEY WATER DISTRICT REQUIRES PIPE BEDDING AND BACKFILL WITHIN THE PIPE ZONE TO BE OF THE SAME MATERIAL.

RTC STD DWG 503

[illegible]