



- NOTES:**
- NO STONES OR LUMPS GREATER THAN 3" PERMITTED IN TRENCH 2" OR LESS IN WIDTH.
 - TRENCH WIDTH, BEDDING, SUBGRADE AND PIPE ZONE REQUIREMENTS FOR UTILITY INSTALLATIONS SHALL CONFORM TO THE RESPECTIVE ENTITY REQUIREMENTS.
 - CRUSHED ROCK MAY BE USED FOR PIPE BEDDING ONLY IF MATERIAL USE HAS BEEN SPECIFICALLY APPROVED BY THE GOVERNING AGENCY. SEE STANDARD DRAWING NO. 505 FOR PIPE BEDDING METHOD.
 - USE USGS VALLEY WATER DISTRICT REQUIREMENTS FOR PIPE BEDDING AND BACKFILL WITHIN THE PIPE ZONE TO BE OF THE SAME MATERIAL.

Call before you Dig
 Avoid locating underground utility lines, to a safety.
Call 811
 1-800-227-2600
 CLARK COUNTY TRADING OPERATIONS
 1-702-455-7544

RTC STD DWG 503

Southwest Gas Corporation

NO.	DESCRIPTION	BY	DATE	APPRD.
1385	REVISIONS			

LINE NO.	UNIT TYPE	INSTL.	RET.	INSTL.	RET.
PROPERTY UNITS					

AS-BUILT DRAWING-PRESSURE TEST DATA

PIPE DIA.	TEST MEDIUM	TEST METHOD
PIPE LENGTH	<input type="checkbox"/> AIR	<input type="checkbox"/> GAUGE
PIPE TYPE	<input type="checkbox"/> NITROGEN	<input type="checkbox"/> CHART
MIN. DURATION	<input type="checkbox"/> WATER	<input type="checkbox"/> GAUGE/ PRESS REC S/W
	<input type="checkbox"/> SOAP	

TEST PRES. (PSIG)	START	END
TIME		
DATE	PROPOSED	COMPLETED
PERFORMED BY		

VISUAL INSPECTION CERTIFICATION

I HAVE VISUALLY INSPECTED ALL HEATED FUSIONS, SOLVENT CEMENT, MECHANICAL JOINTS, AND WELDS THAT I HAVE PERFORMED.

NAME _____ DATE _____

AS-BUILTS ACCEPTED BY _____ DATE _____

POSTED BY _____ DATE _____

POSTING QCD BY _____ DATE _____

CONSTRUCTION

INSPECTOR _____

FOREMAN _____

REVIEWED BY _____

PERMIT INFORMATION

CITY OF LAS VEGAS

TAX CODE 02-0207 / 02-0200

ISOLATION AREA	W. R. NO.
DIST_019	1414593
LOCATION	TILE NO.
T20S, R60E, S24 T20S, R60E, S25 T20S, R61E, S19 M.D.M.	x606y522 x609y522

ENGINEER/TECHNICIAN	RYAN MORGAN	PHONE	365-2172
ACCOUNT REP.		PHONE	
PROJECT CONTACT	RYAN MORGAN	PHONE	365-2172
SHEET NO.	2 OF 9	SCALE	1"=30'
DWN. BY	ZE	CHKD. BY	UPDATED
TITLE			
F-CLV-VEGAS DRIVE STORM DRAIN 4" DIST. STEEL REPLACEMENT			

CPM Utility Plan Approval
 Vegas Drive Improvements
 CPM Project Name
 CPM Hansen # 11554 Date 6/4/12
 CPM Project Manager Lorie Linnert Dunford x6738
 Approved by: *[Signature]*

MATCHLINE - SEE SHEET 3 STA 13+50