



HOPE PIPE CONSTRUCTION NOTE:
 CONTRACTOR SHALL PROVIDE 30" MINIMUM COVER OVER HOPE PIPE PRIOR TO VEHICLE LOADING DURING CONSTRUCTION. TRENCH WIDTH MUST BE WIDE ENOUGH TO ACCOMMODATE COMPACTION EQUIPMENT. SEE MANUFACTURER'S GUIDELINES (PRODUCT NOTE 3.115) AND ASTM D2321. CONTRACTOR SHALL NOT USE HYDRO-HAMMER TYPE COMPACTORS OVER PIPE TRENCH AREA.

RAINBOW BOULEVARD (PUBLIC) PROFILE
 SCALE: HORIZ. 1" = 40'
 VERT. 1" = 4'

APPROVAL FOR CONSTRUCTION
[Signature]
 LAS VEGAS VALLEY WATER DISTRICT
 DATE: 5/1/02

BASIS OF BEARING
 THE BASIS OF BEARING FOR THIS SURVEY IS THE WEST LINE OF THE SOUTHEAST QUARTER (SE 1/4) OF SECTION 15, TOWNSHIP 19 SOUTH, RANGE 80 EAST, M.D.M., CLARK COUNTY, NEVADA, AS SHOWN IN FILE 115, PAGE 13 OF OFFICIAL RECORDS, CLARK COUNTY, NEVADA. I.E. NORTH 001°55' EAST

Call before you do Overhead
 1-702-593-6111

Call before you Dig.
 1-800-227-2600

NO.	DESCRIPTION	DATE	APP'D.

PULTE HOMES
 VILLAGE CENTER CIRCLE, SUITE 250
 LAS VEGAS, NEVADA 89113
 (702) 256-7900

PENTACORE
 CIVIL ENGINEERING, LAND SURVEYING, PLANNING
 CONSTRUCTION MANAGEMENT, ADA CONSULTING
 LAS VEGAS, NEVADA 89148 (702) 258-0115

RAINBOW BOULEVARD
 STA 23+32.36 TO STA 30+00.00
 PLAN AND PROFILE

WETH RANCH
 UNIT 1

DATE: 11/26/01
 DRAWN BY: [Signature]
 CHECKED BY: [Signature]
 JOB NO.: 0147.0231
 ADA NO.: [Signature]
 SCALE: 1" = 40'

PROFESSIONAL ENGINEER - STATE OF NEVADA
 RICHARD P. SENECA
 CIVIL
 11752

SHEET **28** OF 41
 C.L.V. DWG.#

W:\Active\68147028\Drawings\unit_1_plans\01-pp020.DWG aieberger Tue, 30 Apr 2002 - 3:13pm

41418

567 Y-4699