



- NOTES:**
- NO STONES OR LUMPS GREATER THAN 3" PERMITTED IN TRENCH 2' OR LESS IN WIDTH.
 - TRENCH WIDTH, BEDDING, SUBGRADE AND PIPE ZONE REQUIREMENTS FOR UTILITY INSTALLATIONS SHALL CONFORM TO THE RESPECTIVE ENTITY REQUIREMENTS.
 - CRUSHED ROCK MAY BE USED FOR PIPE BEDDING ONLY IF MATERIAL USE HAS BEEN SPECIFICALLY APPROVED BY THE GOVERNING AGENCY. SEE STANDARD DRAWING NO. 505 FOR PIPE BEDDING METHODS.
 - LAS VEGAS VALLEY WATER DISTRICT REQUIRES PIPE BEDDING AND BACKFILL WITHIN THE PIPE ZONE TO BE OF THE SAME MATERIAL.

RTC STD DWG 503

- RTC NOTES:**
 PAVEMENT REPAIR SHALL CONFORM TO RTC STANDARD(S):
 A1 500.4
 A2 500.5

- ABANDONED FACILITIES:**
 1 ABANDON EX. 2" PVC '65 MOP 43#
 2 ABANDON EX. 1/2" PVC '60 SVC

- PROPOSED FACILITIES:**
 1 PROP. 2" PE MAIN
 4 PROP. 2" PE 90° ELBOW (140-3067)
 5 PROP. 1/2" PE SVC



NO.	DESCRIPTION	BY	DATE	APPVD
REVISIONS				

TAX CODES	UNIT NO.	UNIT TYPE	INSTR.	RETIRED	INSTR.	RETIRED
			PROPOSED	COMPLETED		

AS-BUILT DRAWING-PRESSURE TEST DATA	
PIPE DIA.	TEST MEDIUM
PIPE LENGTH	TEST METHOD
PIPE TYPE	MIN. DURATION
TEST PRES. (PSIG)	START
TIME	END
DATE	

VISUAL INSPECTION CERTIFICATION	
I HAVE VISUALLY INSPECTED ALL HEATED FUSIONS, SOLVENT CEMENT, MECHANICAL JOINTS, AND WELDS THAT I HAVE PERFORMED	
NAME	DATE
AS-BUILTS ACCEPTED BY	DATE
POSTED BY	DATE
POSTING COPY BY	DATE

CONSTRUCTION	
INSPECTOR	FOREMAN
REVIEWED BY	
PERMIT INFORMATION	
CITY OF LAS VEGAS	
TAX CODE	

ISOLATION AREA	W.R. NO.
ISO_21 DIST_293	1994603
LOCATION	ATLAS #/TILE #
T21S R61E SEC 3	x630y512

ENGINEER/TECH: MARIA RUSHING	PHONE: 702-365-2008
ACCOUNT REP:	PHONE:
PROJECT CONTACT: MARIA RUSHING	PHONE: 702-365-2008
SHEET NO: 4 OF 5	SCALE: 1" = 40'
DWN. BY: ZONE ENG	CHKD. BY:
DATE: 11/18/14	APPVD. BY:
TITLE	
F-CLV 2015 SS-YUCCA & FRANCIS	