

CAUTION:

BELL SYSTEM CABLE IN
THIRD STREET. CONTACT
OWNER PRIOR TO CONST.

NOTES: (FOR STREET LIGHTS ONLY)

1. ALL LIGHT POLES TO BE LOCATED 1.5' BACK OF CURB.
2. ALL LIGHT POLE FOUNDATIONS SHALL BE AS PER STD. DWG. 403.0.
3. ALL LIGHTING STANDARDS SHALL BE AS NOTED.
4. ALL CONDUITS SHALL BE 1/4" P.V.C., TO BE LOCATED UNDER SIDEWALK WITH A 24" MIN. COVER IN ALL AREAS.
5. LIGHTING SYSTEM TO BE 120/240 VOLT, 60 AMP MULTIPLE RELAY, 400 WATT (TYPE OV 25 WESTINGHOUSE OR EQUAL) LUMINAIRE, TO BE CONNECTED TO 120 VOLT GROUND NEUTRAL TO EACH POLE.
6. WIRE TO BE N# 4 & N# 6 (AS INDICATED), 3 WIRE, 2 COLOR (1 WHITE).

BENCH MARK: CLV #303, ELEV. 2031.69
OBSOLETE AS STAMPED. TO CONVERT TO
NEW CLV DATUM ADD 1.77 FT. TO ALL ELEVATIONS.
CLV #303 IS LOCATED IN CURB APPROX. 115' NORTH OF EXIST. DRIVE.

ALL CONSTRUCTION SHALL CONFORM TO
THE UNIFORM STANDARD SPECIFICATIONS
(AND DRAWINGS) FOR PUBLIC WORKS
CONSTRUCTION FOR CLARK COUNTY AREA.

S O U T H T H I R D S T R E E T

