



NOTES:

1. ALL CONSTRUCTION TO CONFORM TO THE UNIFORM STANDARD SPECIFICATIONS (AND DRAWINGS) FOR PUBLIC WORKS CONSTRUCTION CLARK COUNTY NEVADA.
2. ALL POLES TO BE LOCATED 1.5' BACK OF CURB.
3. ALL STREET LIGHT FOUNDATIONS SHALL BE AS PER STD. DWG. 403.0.
4. ALL LIGHTING STANDARDS SHALL BE 11 GAUGE AS SHOWN BY STD. DWG. 400.15.
5. ALL CONDUITS SHALL BE 1/4 P.V.C. SCHEDULE 40, TO BE LOCATED UNDER SIDEWALK WITH 24" MIN COVER IN ALL AREAS.
6. LIGHTING SYSTEM TO BE 120/240 VOLT, 60 CYCLE, SINGLE PHASE, 3 WIRE, MULTIPLE UNDERGROUND, 400 WATT (TYPE OV25 WESTINGHOUSE, OR EQUAL) LUMINAIRE TO BE CONNECTED TO 240 VOLT GROUND NEUTRAL TO EACH POLE.
7. WIRE SHALL BE 3#2 T.H.W. TWO COLOR (1 WHITE). Service to R.C.O.C. (Other wiring as indicated)

ESTIMATED QUANTITIES

1/4 P.V.C. CONDUIT 1050 L.F.
 11 GAUGE LIGHT POLES 5 EA.
 400 WATT W.M.V. LUMINAIRES 5 EA.

APPROVALS

[Signature]
 CITY ENGINEERS DATE
[Signature] 1-14-78
 CITY ELECTRICIAN DATE
[Signature] 12-9-69
 NEVADA POWER COMPANY DATE

[Stamp]
 1-12
 REC'D 11/17/78
 11/17/78

[Signature] 10-30-69
 DESIGNED BY - RICHARD J. BAUGHMAN - RE 2162 - DATE

REVISIONS		STREET LIGHT DESIGN	
NO.	DATE	BY	
1			
2			
3			
4			
5			

REVIEW JOURNAL			
SEC. 28, T. 20. S., R. 6. E.			
DRAWN BY	SCALE	MATERIAL	
DATE	1"=30'		
CHK'D	DATE	DRAWING NO.	
		69-101	
TRACED	APP'D	DWT: JWA	

LEAVITT & ASSOCIATES
 CONSULTING ENGINEERS - LAND SURVEYORS
 536 EAST SARAH AVENUE LAS VEGAS, NEVADA