



**LAS VEGAS
CITY COUNCIL**

CAROLYN G. GOODMAN
Mayor

STAVROS S. ANTHONY
Mayor Pro Tem

MICHELE FIORE

CEDRIC CREAR

BRIAN KNUDSEN

VICTORIA SEAMAN

OLIVIA DIAZ

JORGE CERVANTES
City Manager

DEPARTMENT OF PLANNING

SETH T. FLOYD

DIRECTOR OF
COMMUNITY DEVELOPMENT

CITY HALL

495 S. MAIN ST.
3RD FLOOR
LAS VEGAS, NV 89101
702.229.6301 | VOICE
702.464.2545 | FAX
711 | TTY



cityoflasvegas
lasvegasnevada.gov

January 20, 2022

Mr. Brett S. Albrecht
FKC Lake Mead, LLC
180 N. Riverview Drive, Ste. 180
Anaheim, CA 92808

**RE: 21-0817-SDR1 – ADMINISTRATIVE SITE DEVELOPMENT PLAN
REVIEW
ADMINISTRATIVE CYCLE – JANUARY 2022**

Dear Applicant:

Your Land Use Entitlement request FOR THE PROPOSED BUILDING REMODEL AND DRIVE THROUGH ADDITION on 8.98 acres at the northwest corner of Lake Mead Boulevard and Jones Boulevard (APN 138-23-618-002), C-1 (Limited Commercial) Zone, Ward 5 (Crear), has been considered administratively by the Department of Planning staff.

The Department of Planning has administratively **APPROVED** your request subject to the following:

Planning

1. Conformance to the Conditions of Approval for Reclassification of Property (Z-0047-90) shall be required, except as amended herein.
2. This approval shall be void two years from the date of final approval, unless exercised pursuant to the provisions of LVMC Title 19.16. An Extension of Time may be filed for consideration by the City of Las Vegas.
3. All development shall be in conformance with the site plan, landscape plan, and building elevations, date stamped 12/21/21, except as amended by conditions herein.
4. All necessary building permits shall be obtained and final inspections shall be completed in compliance with Title 19 and all codes as required by the Department of Building and Safety.
5. These Conditions of Approval shall be affixed to the cover sheet of any plan set submitted for building permit.

6. A technical landscape plan, signed and sealed by a Registered Architect, Landscape Architect, Residential Designer or Civil Engineer, must be submitted prior to or at the same time application is made for a building permit. A permanent underground sprinkler system is required, which shall be permanently maintained in a satisfactory manner; the landscape plan shall include irrigation specifications. Installed landscaping shall not impede visibility of any traffic control device.
7. A fully operational fire protection system, including fire apparatus roads, fire hydrants and water supply, shall be installed and shall be functioning prior to construction of any combustible structures.
8. All City Code requirements and design standards of all City Departments must be satisfied, except as modified herein.

Public Works

9. Coordinate with the Environmental Compliance & Enforcement staff of the Department of Public Works to locate any required grease interceptors, sand/oil interceptors, or separator mitigation in acceptable locations prior to submittal of sewer-related plans. Comply with the recommendations and requirements of the Environmental Compliance & Enforcement staff prior to issuance of permits. The team may be contacted at 702-229-2338 or emailed at ece@lasvegasnevada.gov.
10. Contact the City Engineer's Office at 702-229-6272 to coordinate the development of this project with the "Various Intersection Improvements -Charleston/Torrey Pines and the Lake Mead/Jones" Capital Improvement projects and any other public improvement projects adjacent to this site. Comply with the recommendations of the City Engineer
11. An update to the previously approved Drainage Plan and Technical Drainage Study must be submitted to and approved by the Department of Public Works prior to submittal of any construction drawings or the issuance of any building or grading permits, whichever may occur first. Provide and improve all drainageways recommended in the approved drainage study update.

This action by the Department of Planning staff on **January 20, 2022** is final unless a written appeal is filed with the Director of the Department of Planning within ten days of the date of this letter.

Sincerely,



Eric McCammond
Senior Management Analyst
Department of Planning

21-0817-SDR1 - Page Three
January 20, 2022

EM:nl

c.c.:

Mr. Brett S. Albrecht
Kraemer Land Company, LLC
180 N. Riverview Drive, Ste. 180
Anaheim, CA 92808

Mr. Tim Bundy
Bundy Finkle Architects
1120 Bristol Street, Ste. 120
Costa Mesa, CA 92626