



December 21, 2006

LAS VEGAS CITY COUNCIL

OSCAR B. GOODMAN
MAYOR

GARY REESE
MAYOR PRO TEM

LARRY BROWN
LAWRENCE WEEKLY
STEVE WOLFSON
LOIS TARKANIAN
STEVEN D. ROSS

DOUGLAS A. SELBY
CITY MANAGER

Mr. Sam Ventura
SVS Properties, Limited
4431 South Eastern Avenue, Suite 32
Las Vegas, Nevada 89119

RE: SDR-17211 – SITE DEVELOPMENT PLAN REVIEW
CITY COUNCIL MEETING OF DECEMBER 20, 2006

Dear Mr. Ventura:

The City Council at a regular meeting held December 20, 2006 APPROVED the request for a Site Development Plan Review FOR A 3,560 SQUARE-FOOT ADDITION TO AN EXISTING OFFICE BUILDING AND A WAIVER TO ALLOW A REDUCTION OF PERIMETER LANDSCAPE BUFFER WIDTH REQUIREMENTS on 1.46 acres at 700 East Charleston Boulevard (APN 162-03-501-003), P-R (Professional Office and Parking) Zone. The Notice of Final Action was filed with the Las Vegas City Clerk on December 21, 2006. This approval is subject to:

Planning and Development

1. This approval shall be void two years from the date of final approval, unless a building permit has been issued for the principal building on the site. An Extension of Time may be filed for consideration by the City of Las Vegas.
2. All development shall be in conformance with the site plan and landscape plan date stamped 10/16/06, and building elevations date stamped 09/29/06 and 11/03/06 except as amended by conditions herein.
3. A Waiver to reduce perimeter landscape buffer requirements is hereby approved, to allow three feet along the south property line, zero feet along the east property line and five feet along the west property line.
4. An additional two loading spaces shall be added to the site in accordance with Title 19.10 standards.
5. Pre-planting and post-planting landscape inspections are required to ensure the appropriate plant material, location, size of planters, and landscape plans are being utilized. The Planning and Development Department must be contacted to schedule an inspection prior to the start of the landscape
6. Reflective glazing at the pedestrian level is prohibited. Glazing above the pedestrian level shall be limited to a maximum reflectance rating of 22% (as defined by the National Institute of Standards and Technology).

CITY OF LAS VEGAS
400 STEWART AVENUE
LAS VEGAS, NEVADA 89101

VOICE 702.229.6011
TTY 702.386.9108

www.lasvegasnevada.gov

18112-001-06-05
CLV 7009

ROC-18953
01-17-07 CC


Mr. Sam Ventura
SDR-17211 – Page Two
December 21, 2006

7. All mechanical equipment, air conditioners and trash areas shall be fully screened in views from the abutting streets..
8. All utility boxes exceeding 27 cubic feet in size shall meet the standards of LVMC Title 19.12.040.
9. Parking lot lighting standards shall be no more than 30 feet in height and shall utilize downward-directed lights with full cut-off luminaries. Lighting on the exterior of buildings shall be shielded and shall be downward-directed. Non-residential property lighting shall be directed away from residential property or screened, and shall not create fugitive lighting on adjacent properties.
10. A fully operational fire protection system, including fire apparatus roads, fire hydrants and water supply, shall be installed and shall be functioning prior to construction of any combustible structures.
11. All City Code requirements and design standards of all City Departments must be satisfied, except as modified herein.

Public Works

12. Remove all substandard public street improvements and unused driveway cuts adjacent to this site, if any, and replace with new improvements meeting current City Standards concurrent with development of this site. All existing paving damaged or removed by this development shall be restored at its original location and to its original width concurrent with development of this site.
13. Obtain an Occupancy Permit from the Nevada Department of Transportation for all landscaping and private improvements in the Charleston Boulevard public right-of-way adjacent to this site prior to the issuance of any permits.
14. Meet with the Fire Protection Engineering Section of the Department of Fire Services to discuss fire requirements for the proposed use of this facility.
15. Meet with the Flood Control Section of the Department of Public Works for assistance with establishing finished floor elevations and drainage patterns for this site prior to submittal of construction plans or the issuance of any building or grading permits, whichever may occur first. Provide and improve all drainage ways as recommended.

Sincerely,



Angela Crolli
Deputy City Clerk II for
Barbara Jo Ronemus, City Clerk

cc: See Attached List

ROC-18953
01-17-07 CC