

Silver Dollar Re-Inspection Report 8/31/2009

4186 Silver Dollar

Case Number	Unit	Violations Remaining	Inspection Results	Occupied/Vacant
67914	1	Interior Insp- Previously passed. Leave Case Open for Common Area Inspected 8/31/09 1)Cleanout not to Grade Level	Failed	Occupied
68011	2	No Insp/ Previously passed.	Passed	Occupied
68012	3	No Insp/ Previously passed.	Passed	Occupied
68016	4	No Insp/ Previously passed.	Passed	Occupied
68168	5	Violations repaired.	Passed	Occupied
68013	6	No Insp/ Previously passed.	Passed	Occupied
68014	7	No Insp/ Previously passed.	Passed	Occupied
68171	8	None	Passed	Owner Occupied

4168 Silver Dollar

Case Number	Unit	Violations Remaining	Inspection Results	Occupied/Vacant
68005	1	Violations repaired.	Passed	Occupied
68125	2	No inspection completed- Will be ready on 3/2/09 Inspected 4/30/09 1) Broken door knob assembly 2) Lvngrm window broken 3) GFCI broken-ktchn 4) Kichn snk not secured 5) Hood outlet incomplete 6) Exhaust duct not installed 7) No stove 8) Missing interior door casing 9) Bedroom window broken 10) Circuit Breakers unlabeled 11) Cabinets in disrepair 12) Toilet needs base caulked 13) Incorrect tail piece-lavatory 14) Tub drain backed up 15) Tub shower valve disrepair 16) Bathroom wall unfinished 17) Need electricity	First Fail from boarded status	Vacant
		Inspected 7/10/09 Violations repaired	Passed	Occupied
	3	No inspection completed, will be moved to unit 3 when completed. Then unit to be rehabbed. Not ready for inspection of 4/30/09 Inspected 7/10/09 Violations repaired	Vacant	Now Vacant
68172			Passed	Occupied
68007	4	1)Window broken Inspected 8/31/09 Compliance Made	Passed	Occupied
68173	5	None	Passed	Owner Occupied
68009	6	Violations repaired.	Passed	Occupied

		11)Need electricity Inspected 7/10/09 Violations repaired	Passed	Occupied
	8	No inspection completed, will be completed in March. Inspected 4/30/09: 1)Missing range hood w/exhaust 2)Kitchen cabinets in disrepair 3)Bathroom sink/cabinet not replaced 4)Exhaust fan to have roof flashing 5)Carpet not installed throughout 6)Unusable stove 7)Need electricity Inspected on 7/10/09	First fail from boarded status	Vacant
68472		1)Common Area Clean Out Buried	Failed	Occupied

Items with * are new violations.

Common Area Violations :

- 1) Needs to restore and return the copper water piping as the grounding electrode or repair by other approved means. – Inspector verified repaired.
- 2) Interior area landscaping has been completed.
- 3) Repair all damaged stucco to exterior areas of building. This item was completed.
- *4) Common Area at 4152 is to have cleanout raised to grade level. As of 8/31/09 this has not been completed.
- *5) Common Area at 4186 is to have back flow protection at front landscape connection. As of 8/31/09 this has not been completed.