



LAS VEGAS CITY COUNCIL

OSCAR B. GOODMAN
MAYOR

GARY REESE
MAYOR PRO TEM

LARRY BROWN
STEVE WOLFSON
LOIS TARKANIAN
STEVEN D. ROSS
RICKI Y. BARLOW

DOUGLAS A. SELBY
CITY MANAGER

CITY OF LAS VEGAS
400 STEWART AVENUE
LAS VEGAS, NEVADA 89101

VOICE 702.229.6011
TDD 702.386.9108
www.lasvegasnevada.gov

RECEIVED

OCT 24 2007

GMRA

October 19, 2007

Mr. Bradley Hofland, President
Wayward Properties, Inc.
4495 South Pecos Road, Suite A
Las Vegas, Nevada 89121

RE: SDR-18925 – SITE DEVELOPMENT PLAN REVIEW
CITY COUNCIL MEETING OF OCTOBER 17, 2007
RELATED TO ZON-18923, VAR-18924 AND VAR-19609

Dear Mr. Hofland:

The City Council at a regular meeting held October 17, 2007 APPROVED the request for a Site Development Plan Review FOR A TWO-STORY, 3,218 SQUARE FOOT PROFESSIONAL OFFICE BUILDING WITH WAIVERS TO ALLOW PERIMETER LANDSCAPE BUFFER WIDTHS OF FOUR FEET ON THE NORTH AND ZERO FEET ON SOUTH PROPERTY LINES WHERE EIGHT FEET IS THE MINIMUM REQUIRED on 0.16 acres at 514 South Seventh Street (APN 139-34-710-024), R-1 (Single Family Residential) Zone [PROPOSED: P-R (Professional Office and Parking)]. NOTE: THIS APPLICATION HAS BEEN AMENDED FROM 3,025 SQUARE FEET TO 3,299 SQUARE FEET. The Notice of Final Action was filed with the Las Vegas City Clerk on October 18, 2007. This approval is subject to:

Planning & Development

1. Conformance to the conditions for Rezoning (ZON-18923), Variance (VAR-18924), and Variance (VAR-19609) if approved.
2. This approval shall be void two years from the date of final approval, unless a building permit has been issued for the principal building on the site. An Extension of Time may be filed for consideration by the City of Las Vegas.
3. All development shall be in conformance with the site plan, landscape plan and building elevations date stamped 07/12/07, except as amended by conditions herein.
4. A Waiver from Title 19.12.040A is hereby approved, to allow a perimeter landscape buffer width of four feet on the north and zero feet on south property lines where five feet is the minimum required.
5. An exception from Title 19.10.010 (J11) Parking, Loading, and Traffic Standards is hereby approved, to allow zero parking lot fingers where two parking lot fingers are required.

EOT-36227
12-02-09 CC

6. A technical landscape plan, signed and sealed by a Registered Architect, Landscape Architect, Residential Designer or Civil Engineer, must be submitted prior to or at the same time application is made for a building permit. A permanent underground sprinkler system is required, and shall be permanently maintained in a satisfactory manner; the landscape plan shall include irrigation specifications.
7. Pre-planting and post-planting landscape inspections are required to ensure the appropriate plant material, location, size of planters, and landscape plans are being utilized. The Planning and Development Department must be contacted to schedule an inspection prior to the start of the landscape installation and after the landscape installation is completed. A certificate of occupancy will not be issued or the final inspection will not be approved until the landscape inspections have been completed.
8. Reflective glazing at the pedestrian level is prohibited. Glazing above the pedestrian level shall be limited to a maximum reflectance rating of 22% (as defined by the National Institute of Standards and Technology).
9. All mechanical equipment, air conditioners and trash areas shall be fully screened in views from the abutting streets.
10. All utility boxes exceeding 27 cubic feet in size shall meet the standards of LVMC Title 19.12.040.
11. Parking lot lighting standards shall be no more than 30 feet in height and shall utilize downward-directed lights with full cut-off luminaries. Lighting on the exterior of buildings shall be shielded and shall be downward-directed. Non-residential property lighting shall be directed away from residential property or screened, and shall not create fugitive lighting on adjacent properties.
12. A fully operational fire protection system, including fire apparatus roads, fire hydrants and water supply, shall be installed and shall be functioning prior to construction of any combustible structures, subject to the requirements of the Fire Marshal.
13. All City Code requirements and design standards of all City Departments must be satisfied, except as modified herein.

Public Works

14. All landscaping and private improvements installed with this project shall be situated and maintained so as to not create sight visibility obstructions for vehicular traffic at all development access drives and abutting street intersections.
15. Site development to comply with all applicable conditions of approval for Zoning Reclassification ZON-18923 and all other subsequent site-related actions.

Mr. Bradley Hofland
SDR-18925 – Page Three
October 19, 2007

16. Coordinate with the City Surveyor regarding recordation of a Reversionary Map for this site; comply with the recommendations of the City Surveyor.
17. Remove all substandard public street improvements and unused driveway cuts adjacent to this site, if any, and replace with new improvements meeting current City Standards concurrent with development of this site. All existing paving damaged or removed by this development shall be restored at its original location and to its original width concurrent with development of this site.
18. Landscape and maintain all unimproved rights-of-way, if any, on Seventh Street adjacent to this site.
19. Submit an Encroachment Agreement for all landscaping and private improvements, if any, located in the Seventh Street public right-of-way adjacent to this site prior to occupancy of this site.
20. Meet with the Flood Control Section of the Department of Public Works for assistance with establishing finished floor elevations and drainage paths for this site prior to submittal of construction plans or the issuance of any building or grading permits, whichever may occur first. Provide and improve all drainage ways as recommended.

Sincerely,



Angela Crolli
Deputy City Clerk II for
Beverly K. Bridges, CMC, City Clerk

cc: Planning and Development Dept.
Development Coordination-DPW
Dept. of Fire Services

Mr. George Rogers
6325 South Jones Boulevard, Suite #100
Las Vegas, Nevada 89118

EOT-36227
12-02-09 CC