

From: Daniel LaRubio [<mailto:larubio@snhdmail.org>]

Sent: Monday, May 08, 2017 4:02 PM

To: Keith Letus; Robert Fyda; Jacqueline Reszetar

Cc: Raul Cruz-Santiago; Tim Parks; Joe Pena; Roger Bailey; Bart Anderson; Lucien Paet; Victor Bolanos

Subject: RE: SDR-70261, SDR-70279 - ISDS on 4505 & 4515 Balsam - APN 138-03-602-008 & 138-03-602-007

Keith,

Both of these two properties have septic systems that will be under pavement adjacent to Balsam St. SNHD recommends that these properties don't try to use these septic systems based on a violation of the SNHD ISDS Regulation Section 11.15 which states that *An individual sewage disposal system is prohibited in an area subject to vehicular access or traffic, or any area to be paved.* Therefore, since sewer is available, the properties must connect to CLV sewer.

PRJ-70049
05/11/17

Thank you,

Dan

Daniel LaRubio, Jr., P.E., REHS

Environmental Health Engineer/Supervisor

Environmental Health Division

Southern Nevada Health District

Physical Address: 333 N. Rancho Drive - Suite 450, Las Vegas, NV 89107

Mailing Address: P.O Box 3902, Las Vegas, NV 89127

TELE: (702) 759-0660

FAX: (702) 759-1427

E-MAIL: larubio@snhdmail.org

Please consider the environment before printing this email 

Do not read, copy or disseminate this information unless you are the intended recipient. This email and any attachments are confidential and, except where the email specifically states it can be disclosed, it may also be privileged. If you have received this communication in error, please notify the sender immediately at 702-759-0617 or by email. Additionally, if received in error, please do not disclose the contents to anyone and delete this email and any attachments. Thank you

VAR-70276, VAR-70277 and SDR-70279