

Steve Jones

From: Michael Anderson <manderson@water.nv.gov>
Sent: Wednesday, December 09, 2015 2:14 PM
To: Steve Jones
Cc: Edmund Quaglieri; Luke Opperman
Subject: Skye Canyon

Steve;

We have reviewed the clarifications and revisions you provided. On final review we note that the detail 6 on sheet D-1 "RCP Trench Detail (TYP)" is now in conflict with the specifications vis. the exception to material and compactive effort under the embankment footprint. It appears that the call-outs for the sub-grade and immediate back-fill need an asterisk (*) like the top-fill call-out.

We'd like this revised since the plans take precedence over the specifications in a conflict.

Thank you,

Mike!

p.s. Picky, aren't we?

Michael J. Anderson, P.E.

Safety of Dams

Nevada Division of Water Resources

901 South Stewart Street, Suite 2002

Carson City, Nevada 89701-5250

(775) 684-2843 ofc.

(775) 684-2810 fax.