

OLY1401.004

December 14, 2015

Michael J. Anderson, P.E.
Safety of Dams
Nevada Division of Water Resources
901 South Stewart Street, Suite 2002
Carson City, NV 89701

**Subject: Request for Additional Information from Nevada Dam Safety for
Skye Canyon Detention Basin 1 (J-716)**

Dear Mr. Anderson:

The following is responses to the item requested via email from Nevada Division of Water Resources – Dam Safety, dated December 9, 2015, to complete review of the Skye Canyon Detention Basin 1 project. The comment has been individually addressed as follows:

1. **Comment:** *On final review we note that the detail 6 on sheet D-1 "RCP Trench Detail (TYP)" is now in conflict with the specifications vis. the exception to material and compactive effort under the embankment footprint. It appears that the call-outs for the sub-grade and immediate back-fill need an asterisk (*) like the top-fill call-out.*

Response: After email coordination, the asterisk calling for 95% compaction of selected backfill material or CLSM has been added to the pipe zone in the embankment and an additional double asterisk requiring CLSM for pipe bedding has been added in the embankment construction area.

Respectfully Submitted,

SLATER HANIFAN GROUP

Steve Jones, P.E.
Project Manager - Flood Control Division

cc: Marc Bolduc – Olympia Companies
Bobby Williamson – Olympia Companies
Jerry Slater, P.E. – SHG
Mark Failla, P.E., CFM – SHG

