

DS #: 5104-1

APN: 137-22-101-001, 137-21-060-002

PROJECT: Master Conceptual Drainage Study - Update #1
for Summerlin West Village 25

SUBMITTAL: CORRECTED

SCANNED BY/DATE:

CHECKED BY/DATE:



CITY OF LAS VEGAS		DATE:
INTER-OFFICE MEMORANDUM		April 14, 2020
TO: Land Development Services Department of Building & Safety		FROM: Albert Sung, P.E. Flood Control Project Engineer Department of Public Works
SUBJECT:	COPIES TO:	
Drainage Study for:	VTN Nevada	
Master Conceptual Drainage Study – Update #1 For Summerlin West Village 25		
Cross Streets:	Sky Vista Drive and Far Hills Avenue	Howard Hughes Company, LLC
File Number:	F:\Depot\DSMemos\DS5104F.doc	Bart Anderson, P.E., DevCo
Parcel Number:	137-22-101-001, 137-21-000-002	CCRFC
Zoning Action:	MDR-75107 & PMP-74780	
FEMA Flood Zone	YES NO X	
Proposed Storm Drain	YES X NO	

HISTORY	DATE RECEIVED	DATE REVIEWED	COMMENTS	REVIEW FEES	FEES PAID Payment Trn #
1 st Submittal	2/20/2019	2/27/2019 & 3/20/2019	Not Approved	\$400.00	503292: \$400
2 nd Submittal	4/4/2019	4/17/2019	Not Approved	\$400.00	3081574: \$400
3 rd Submittal	4/25/2019	5/9/2019	Conditional Approval	\$400.00	3105175: \$400
CCRFC	6/10/2019	6/18/2019	Concurrence Recv'd	N/C	N/C
4 th Submittal	12/26/2019	1/23/2020	Conditional Approval	\$100.00	3686588: \$100
CCRFC	3/23/2020	4/14/2020	Concurrence Recv'd	N/C	N/C
TOTAL FEES (LDDRS):				\$1,300.00	----

REMARKS:

4th Submittal: Update to revise the layout of V25 to match the changes to the overall Summerlin West Planning Area land plan

The Drainage Study for the subject project has been reviewed and:

X	is approved subject to conformance to all City standards and the following conditions:
	must be resubmitted or supplemented including the following:
	is conditionally approved subject to Clark County Regional Flood Control District concurrence.
	is conditionally approved subject to Clark County Public Works Department concurrence.

- The *Grand Park Detention Basin* is proposed to regulate and meter outflow to match the previously approved downstream flow conditions at the junction of *Far Hills* storm drain and the *Beltway Channel*. Without the *Grand Park Detention Basin*, there will be a net increase in flows at the *Beltway Channel* downstream of *Far Hills* intersection exceeding the previously approved flow.

A technical drainage study for the analysis, design and construction plans for the *Grand Park Detention Basin* must be submitted and approved by the City prior to the individual onsite parcel developments.


NOTE: Any future changes to the proposed design (or design assumptions) as outlined in the approved drainage study and attached preliminary grading plan which affect drainage must be addressed in a Drainage Study Update and accepted by the *City of Las Vegas Flood Control Section*. Additionally, conditional acceptance of a drainage study is valid for a period of one (1) year. If the proposed construction has not been completed in that time period, the *City of Las Vegas* reserves the right to require additional conditions and/or submission and acceptance of a complete drainage study update prior to further construction of a project.

NOTE: Please be advised that all land surface area disturbances over 1 acre or any area adjacent to a water way must submit to the Nevada Division of Environmental Protection a "Notice of Intent" to discharge that certifies a stormwater pollution prevention plan has been developed and is maintained on site; for inclusion in the Stormwater General Permit No. NVR100000. A phased construction unit in a contiguous subdivision is considered under construction until all stripped or disturbed surface areas have been covered by paving, building construction or planting. For more information, including forms and applications see <http://ndep.nv.gov/bwpc/storm01.htm> or call (775) 687-9429.

END OF REMARKS
WSP/AYS

T/R/S: T20S/R59E/22
AREA K-22

REGIONAL FLOOD CONTROL DISTRICT



Steven C. Parrish, P.E.
General Manager/Chief
Engineer

BOARD OF DIRECTORS

Lawrence L. Brown, III
Chair
Clark County

Mayor Debra March
Vice-Chair
City of Henderson

George Gault
City of Mesquite

James B. Gibson
Clark County

Mayor Carolyn Goodman
City of Las Vegas

Stavros Anthony
City of Las Vegas

Isaac Barron
City of North Las Vegas

Mayor Kiernan McManus
City of Boulder City

March 23, 2020

Mr. Oh Sang Kwon, P.E.
City of Las Vegas Department of Public Works
333 North Rancho Drive
Las Vegas, NV 89106

**DISTRICT CONCURRENCE: UPDATE #1 FOR SUMMERLIN WEST VILLAGE 25
(DS5104E) (RFCD No. 20-12439)**

Dear Mr. Kwon:

Clark County Regional Flood Control District (District) reviewed Conceptual Drainage Study dated December 23, 2019 for above-mentioned project as submitted by VTN NEVADA. In addition, District is in receipt of the Conditional Letter of Acceptance from City of Las Vegas Department of Public Works dated January 23, 2020.


District concurs with acceptance of this Technical Drainage Study by City of Las Vegas Department of Public Works.

District's review of this project was limited to issues of Regional Flood Control Significance as defined in *Uniform Regulations for the Control of Drainage*.

Please be aware that as additional information becomes available and/or restudies of Flood Insurance Studies are performed, information submitted by VTN NEVADA may be superseded. Compliance with regulatory elements and design standards specified in *Uniform Regulations for the Control of Drainage* does not imply a guarantee that properties will be free from flooding or flood damage. The District, its officials, or employees assume no liability for information, data, or conclusions presented by consulting engineers. We, therefore, make no warranties, either expressed or implied, in conducting this review.

STEVEN C. PARRISH, P.E.
General Manager/Chief Engineer

BY:


Ching C. Wang, P.E.
Senior Civil Engineer

CCW:jb

c: Brian Troy Ruiz, P.E., VTN Nevada

P:\Letters and Memos\Local Drainage\Land Development & Drainage\2020\L-20-12439.doc

REGIONAL FLOOD CONTROL DISTRICT



Steven C. Parrish, P.E.
General Manager/Chief
Engineer

BOARD OF DIRECTORS

Lawrence L. Brown, III
Chair
Clark County

Mayor Debra March
Vice-Chair
City of Henderson

George Gault
City of Mesquite

James B. Gibson
Clark County

Mayor Carolyn Goodman
City of Las Vegas

Stavros Anthony
City of Las Vegas

Isaac Barron
City of North Las Vegas

Mayor Kiernan McManus
City of Boulder City

March 23, 2020

Mr. Oh Sang Kwon, P.E.
City of Las Vegas Department of Public Works
333 North Rancho Drive
Las Vegas, NV 89106

**DISTRICT CONCURRENCE: UPDATE #1 FOR SUMMERLIN WEST VILLAGE 25
(DS5104E) (RFCD No. 20-12439)**

Dear Mr. Kwon:

Clark County Regional Flood Control District (District) reviewed Conceptual Drainage Study dated December 23, 2019 for above-mentioned project as submitted by VTN NEVADA. In addition, District is in receipt of the Conditional Letter of Acceptance from City of Las Vegas Department of Public Works dated January 23, 2020.


District concurs with acceptance of this Technical Drainage Study by City of Las Vegas Department of Public Works.

District's review of this project was limited to issues of Regional Flood Control Significance as defined in *Uniform Regulations for the Control of Drainage*.

Please be aware that as additional information becomes available and/or restudies of Flood Insurance Studies are performed, information submitted by VTN NEVADA may be superseded. Compliance with regulatory elements and design standards specified in *Uniform Regulations for the Control of Drainage* does not imply a guarantee that properties will be free from flooding or flood damage. The District, its officials, or employees assume no liability for information, data, or conclusions presented by consulting engineers. We, therefore, make no warranties, either expressed or implied, in conducting this review.

STEVEN C. PARRISH, P.E.
General Manager/Chief Engineer

BY:


Ching C. Wang, P.E.
Senior Civil Engineer

CCW:jb

c: Brian Troy Ruiz, P.E., VTN Nevada

P:\Letters and Memos\Local Drainage\Land Development & Drainage\2020\L-20-12439.doc