

DS #:

05219

APN:

137-22-101-001

PROJECT:


Summerlin Village 25 Grand Park Boulevard Improvements
- Street "M" to Fox Hill Drive

SUBMITTAL:

CCRFCD

SCANNED BY/DATE:

CHECKED BY/DATE:



CITY OF LAS VEGAS		DATE:
INTER-OFFICE MEMORANDUM		December 23, 2020
TO: Land Development Services Department of Building & Safety		FROM: Albert Sung, P.E. Flood Control Project Engineer Department of Public Works
SUBJECT: Drainage Study for: Summerlin Village 25 Grand Park Boulevard Improvements - Street "M" to Fox Hill Drive		COPIES TO: GCW Inc.
Cross Streets:	Grand Park Boulevard & Redpoint Drive	Howard Hughes Company, LLC
File Number:	F:\Depot\DSMemos\DS5219C.doc	Bart Anderson, P.E., DevCo
Parcel Number:	137-22-101-001	CCRFC
Zoning Action:	N/A	
FEMA Flood Zone	YES NO X	
Proposed Storm Drain	YES X NO	

HISTORY	DATE RECEIVED	DATE REVIEWED	COMMENTS	REVIEW FEES	FEES PAID Payment Trn #
1 st Submittal	11/19/2019 & 12/4/2019	12/17/2019	Not Approved	\$400.00	3651174: \$400
2 nd Submittal	10/15/2020	10/29/2020	Conditional Approval	\$400.00	4032497: \$400
CCRFC	12/10/2020	12/23/2020	Concurrence Recv'd	N/C	N/C
TOTAL FEES (LDDRS):				\$800.00	----

REMARKS:

The Drainage Study for the subject project has been reviewed and:

X	is approved subject to conformance to all City standards and the following conditions:
	must be resubmitted or supplemented including the following:
	is conditionally approved subject to Clark County Regional Flood Control District concurrence.
	is conditionally approved subject to Clark County Public Works Department concurrence.

- The project proposed to construct temporary drainage facilities including drainage berms/ditches along the west side of *Grand Park Boulevard*. Prior to the final plans approval, the developer must complete a **Maintenance & Liability Agreement** for the interim drainage improvements and post a minimum maintenance bond of \$50,000 or 50-percent of the construction cost for the improvements, whichever is greater. The engineer must submit an estimate of the quantities for constructing the facilities and an exhibit that adequately shows the location and limits of the drainage facilities to *City Flood Control* for approval. Once the drainage study is conditionally approved, the engineer/developer should contact the *City's Land Development Section* (702-229-6371) to begin the agreement process.

In order for the maintenance bond to be released in the future, a drainage update/letter will be required to justify that the berm/swale are no longer necessary and can be removed.


- All offsite interim flood control facilities such as but not limited to berms/ditches and temporary sump are privately owned and to be privately maintained by the *Howard Hughes Company*.

NOTE: Any future changes to the proposed design (or design assumptions) as outlined in the approved drainage study and attached preliminary grading plan which affect drainage must be addressed in a Drainage Study Update and accepted by the *City of Las Vegas Flood Control Section*. Additionally, conditional acceptance of a drainage study is valid for a period of one (1) year. If the proposed construction has not been completed in that time period, the *City of Las Vegas* reserves the right to require additional conditions and/or submission and acceptance of a complete drainage study update prior to further construction of a project.

NOTE: Please be advised that all land surface area disturbances over 1 acre or any area adjacent to a water way must submit to the Nevada Division of Environmental Protection a "Notice of Intent" to discharge that certifies a stormwater pollution prevention plan has been developed and is maintained on site; for inclusion in the Stormwater General Permit No. NVR100000. A phased construction unit in a contiguous subdivision is considered under construction until all stripped or disturbed surface areas have been covered by paving, building construction or planting. For more information, including forms and applications see <http://ndep.nv.gov/bwpc/storm01.htm> or call (775) 687-9429.

END OF REMARKS
HDR/AYS

T/R/S: T20S/R59E/22
AREA K-22



Reid: 12/10/20
DS05219
N/C

Steven C. Parrish, P.E.
General Manager/Chief
Engineer

BOARD OF DIRECTORS

Lawrence L. Brown, III
Chair
Clark County

Mayor Debra March
Vice-Chair
City of Henderson

George Gault
City of Mesquite

James B. Gibson
Clark County

Mayor Carolyn Goodman
City of Las Vegas

Mayor Pro Tem
Stavros Anthony
City of Las Vegas

Isaac Barron
City of North Las Vegas

Mayor Kiernan McManus
City of Boulder City

December 10, 2020

Mr. Oh Sang Kwon, P.E.
City of Las Vegas Department of Public Works
333 North Rancho Drive
Las Vegas, NV 89106

**DISTRICT CONCURRENCE: VILLAGE 25 GRAND PARK BOULEVARD IMPROVEMENTS
(STREET 'M' TO FOX HILL DR)
(DS5219B) (RFC No. 20-13673)**

Dear Mr. Kwon:


Clark County Regional Flood Control District (District) reviewed Technical Drainage Study dated November 19, 2019, and Addendum No. 1 dated October 15, 2020 for above-mentioned project as submitted by GCW, INC. In addition, District is in receipt of the Conditional Letter of Acceptance from City of Las Vegas Department of Public Works dated October 29, 2020.

District concurs with acceptance of this Technical Drainage Study by City of Las Vegas Department of Public Works.

District's review of this project was limited to issues of Regional Flood Control Significance as defined in *Uniform Regulations for the Control of Drainage*.

Please be aware that as additional information becomes available and/or restudies of Flood Insurance Studies are performed, information submitted by GCW, INC. may be superseded. Compliance with regulatory elements and design standards specified in *Uniform Regulations for the Control of Drainage* does not imply a guarantee that properties will be free from flooding or flood damage. The District, its officials, or employees assume no liability for information, data, or conclusions presented by consulting engineers. We, therefore, make no warranties, either expressed or implied, in conducting this review.

STEVEN C. PARRISH, P.E.
General Manager/Chief Engineer

BY: 
Ching C. Wang, P.E.
Senior Civil Engineer

CCW:jr

c: Mohammad Masih Edalat. Ph.D., P.E., GCW, INC.

P:\Letters and Memos\Local Drainage\Land Development & Drainage\2020\L-20-13673.doc