

CITY OF LAS VEGAS		DATE:
INTER-OFFICE MEMORANDUM		February 14, 2022
TO: Land Development Services Department of Building & Safety		FROM: Albert Sung, P.E. Flood Control Project Engineer Department of Public Works
SUBJECT:	Drainage Study for:	COPIES TO:
Gateway Project		Actus
Cross Streets:	SWC of Las Vegas Blvd. & Park Paseo Drive	Borg Development, LLC
File Number:	F:\Depot\DSMemos\DS5509C.doc	Bart Anderson, P.E., DevCo
Parcel Number:	162-03-112-017,005 & 162-03-116-001,002,003,004,005,009	
Zoning Action:	21-0585-TMP1	
FEMA Flood Zone	YES	NO X
Proposed Storm Drain	YES X	NO

HISTORY	DATE RECEIVED	DATE REVIEWED	COMMENTS	REVIEW FEES	FEES PAID Payment Trn #
1 st Submittal	10/13/2021	11/9/2021	Not Approved	\$400.00	4493749: \$400
2 nd Submittal	12/2/2021	12/21/2021	Not Approved	\$400.00	4558257: \$400
3 rd Submittal & Supplement	1/13/2022 & 2/8/2022	2/14/2022	See Comments Below	\$400.00	4606321: \$400
TOTAL FEES (LDDRS):				\$1,200.00	----

REMARKS:

The Drainage Study for the subject project has been reviewed and:

X	is approved subject to conformance to all City standards and the following conditions:
	must be resubmitted or supplemented including the following:
	is conditionally approved subject to Clark County Regional Flood Control District concurrence.
	is conditionally approved subject to Clark County Public Works Department concurrence.

- Third Request:** *Details 2 and 9 on Sheet C5:* Provide a 2'-high solid grouted flood wall.

NOTE: Please be advised that all land surface area disturbances over 1 acre or any area adjacent to a water way must submit to the Nevada Division of Environmental Protection a "Notice of Intent" to discharge that certifies a stormwater pollution prevention plan has been developed and is maintained on site; for inclusion in the Stormwater General Permit No. NVR100000. A phased construction unit in a contiguous subdivision is considered under construction until all stripped or disturbed surface areas have been covered by paving, building construction or planting. For more information, including forms and applications see <http://ndep.nv.gov/bwpc/storm01.htm> or call (775) 687-9429.

NOTE: Any future changes to the proposed design (or design assumptions) as outlined in the approved drainage study and attached preliminary grading plan which affect drainage must be addressed in a Drainage Study Update and accepted by the *City of Las Vegas Flood Control Section*. Additionally, conditional acceptance of a drainage study is valid for a period of one (1) year. If the proposed construction has not been completed in that time period, the *City of Las Vegas* reserves the right to require additional conditions and/or submission and acceptance of a complete drainage study update prior to further construction of a project.

END OF REMARKS
HDR/JKS

T/R/S: T21S/R61E/03
AREA R-03