

CITY OF LAS VEGAS INTER-OFFICE MEMORANDUM			DATE: December 8, 2021
TO: Land Development Services Department of Building & Safety			FROM: Albert Sung, P.E. Flood Control Project Engineer Department of Public Works
SUBJECT:		Drainage Study for: Valley Vista 1.1 - Project in CNLV for CLV concurrence	COPIES TO: Triton Engineering DR Horton
Cross Streets:	SEC of Grand Teton Drive & Decatur Blvd		
File Number:	F:\Depot\DSMemos\DS5523A.doc		Bart Anderson, P.E., DevCo
Parcel Number:	124-18-110-001		CNLV
Zoning Action:	N/A		
FEMA Flood Zone	YES	NO X	
Proposed Storm Drain	YES X	NO	

HISTORY	DATE RECEIVED	DATE REVIEWED	COMMENTS	REVIEW FEES	FEES PAID Payment Trn #
1 st Submittal	11/30/2021	12/02/2021	Approved	\$400.00	4565551: \$400
TOTAL FEES (LDDRS):				\$400.00	----

REMARKS:

The Drainage Study for the subject project has been reviewed and:

X	is approved subject to conformance to all City standards and the following conditions:
	must be resubmitted or supplemented including the following:
	is conditionally approved subject to Clark County Regional Flood Control District concurrence.
	is conditionally approved subject to Clark County Public Works Department concurrence.

City of Las Vegas Flood Control staff has reviewed the Technical Drainage Study, including Addendum #1 and Addendum #2, for the subject development "**Valley Vista 1.1 Residential Development**" within the jurisdiction of the **City of North Las Vegas**. **City of Las Vegas** concurs with the acceptance of the drainage study by the **City of North Las Vegas Public Works Department**. The review of this project was limited to issues of flood control significance to the **City of Las Vegas**.

NOTE: Any future changes to the proposed design (or design assumptions) as outlined in the approved drainage study and attached preliminary grading plan which affect drainage must be addressed in a Drainage Study Update and accepted by the *City of Las Vegas Flood Control Section*. Additionally, conditional acceptance of a drainage study is valid for a period of one (1) year. If the proposed construction has not been completed in that time period, the *City of Las Vegas* reserves the right to require additional conditions and/or submission and acceptance of a complete drainage study update prior to further construction of a project.

NOTE: Please be advised that all land surface area disturbances over 1 acre or any area adjacent to a water way must submit to the *Nevada Division of Environmental Protection* a "Notice of Intent" to discharge that certifies a stormwater pollution prevention plan has been developed and is maintained on site; for inclusion in the Stormwater General Permit No. NVR100000. A phased

construction unit in a contiguous subdivision is considered under construction until all stripped or disturbed surface areas have been covered by paving, building construction or planting. For more information, including forms and applications see <http://ndep.nv.gov/bwpc/storm01.htm> or call (775) 687-9429.

END OF REMARKS
AYS/NW

T/R/S: T19S/R61E/18
AREA H-18