

CITY OF LAS VEGAS		DATE:
INTER-OFFICE MEMORANDUM		July 16, 2022
TO: Land Development Services Department of Building & Safety		FROM: Albert Sung, P.E. Flood Control Project Engineer Department of Public Works
SUBJECT:	Drainage Study for:	COPIES TO:
Surelink RV & Boat Storage		Balova Engineering
Cross Streets:	SEC of Simmons Street and Holly Avenue	Holly & Simmons, LLC
File Number:	F:\Depot\DSMemos\DS5546C.doc	Bart Anderson, P.E., DevCo
Parcel Number:	139-20-817-001	
Zoning Action:	21-0348-SDR1	
FEMA Flood Zone	YES	NO X
Proposed Storm Drain	YES	NO X

HISTORY	DATE RECEIVED	DATE REVIEWED	COMMENTS	REVIEW FEES	FEES PAID Payment Trn #
1 st Submittal	2/15/2022 & 3/9/2022	3/18/2022	Not Approved	\$400.00	4652163: \$400
2 nd Submittal (Paid on 6/7/2022)	5/26/2022 & 6/7/2022	6/8/2022	Not Approved	\$400.00	4820247: \$400
3 rd Submittal (Paid on 7/16/2022)	6/30/2022	7/16/2022	See Comments Below	\$400.00	4867729: \$400
			TOTAL FEES (LDDRS):	\$1,200.00	----

REMARKS:

The Drainage Study for the subject project has been reviewed and:

X	is approved subject to conformance to all City standards and the following conditions:
	must be resubmitted or supplemented including the following:
	is conditionally approved subject to Clark County Regional Flood Control District concurrence.
	is conditionally approved subject to Clark County Public Works Department concurrence.

NOTE: Any future changes to the proposed design (or design assumptions) as outlined in the approved drainage study and attached preliminary grading plan which affect drainage must be addressed in a Drainage Study Update and accepted by the *City of Las Vegas Flood Control Section*. Additionally, conditional acceptance of a drainage study is valid for a period of one (1) year. If the proposed construction has not been completed in that time period, the *City of Las Vegas* reserves the right to require additional conditions and/or submission and acceptance of a complete drainage study update prior to further construction of a project.

NOTE: Please be advised that all land surface area disturbances over 1 acre or any area adjacent to a water way must submit to the Nevada Division of Environmental Protection a "Notice of Intent" to discharge that certifies a stormwater pollution prevention plan has been developed and is maintained on site; for inclusion in the Stormwater General Permit No. NVR100000. A phased construction unit in a contiguous subdivision is considered under construction until all stripped or disturbed surface areas have been covered by paving, building construction or planting. For more information, including forms and applications see <http://ndep.nv.gov/bwpc/storm01.htm> or call (775) 687-9429.

END OF REMARKS
HDR/PBJ/AYS

T/R/S: T20S/R61E/S20
AREA M-20