



**LAS VEGAS  
CITY COUNCIL**

CAROLYN G. GOODMAN  
Mayor

STAVROS S. ANTHONY  
Mayor Pro Tem

MICHELE FIORE

CEDRIC CREAR

BRIAN KNUDSEN

VICTORIA SEAMAN

OLIVIA DIAZ

JORGE CERVANTES  
City Manager

DEPARTMENT OF PLANNING

**SETH T. FLOYD**

DIRECTOR OF  
COMMUNITY DEVELOPMENT

**CITY HALL**

495 S. MAIN ST.

3RD FLOOR

LAS VEGAS, NV 89101

702.229.6301 | VOICE

702.464.2545 | FAX

711 | TTY



cityoflasvegas  
lasvegasnevada.gov

October 19, 2022

Daniel Sullivan  
PRE Rancho Craig LLC  
One Marina Park Drive Suite 1500  
Boston, Massachusetts 02210

**RE: 22-0174 [VAR1 AND SDR1]  
CITY COUNCIL MEETING OF OCTOBER 19, 2022**

Dear Applicant:

The City Council at a regular meeting held on *October 19, 2022* voted to **APPROVE** the following Land Use Entitlement project requests on 20.76 acres on the South Side of Craig Road, approximately 470 feet east of Rancho Drive (APN 138-02-715-008), C-2 (General Commercial) Zone, Ward 5 (Crear)

**22-0174-VAR1 - VARIANCE - TO ALLOW A 95-FOOT RESIDENTIAL ADJACENCY SETBACK WHERE 97 FEET IS REQUIRED**

**22-0174-SDR1 - SITE DEVELOPMENT PLAN REVIEW - FOR A PROPOSED 41,103 SQUARE-FOOT HEALTH CLUB**

This approval is subject to the following conditions:

**22-0174-VAR1 Conditions:**

**Planning**

1. Approval of and conformance to the approved conditions of approval for Site Development Plan Review (22-0174-SDR1) shall be required, if approved.
2. This approval shall be void two years from the date of final approval, unless exercised pursuant to the provisions of LVMC Title 19.16. An Extension of Time may be filed for consideration by the City of Las Vegas.
3. All necessary building permits shall be obtained and final inspections shall be completed in compliance with Title 19 and all codes as required by the Department of Building and Safety.
4. These Conditions of Approval shall be affixed to the cover sheet of any plan set submitted for building permit.
5. All City Code requirements and design standards of all City departments must be satisfied, except as modified herein.

**22-0174-SDR1 Conditions:**

**Planning**

1. 36-inch box shade trees shall be planted within the perimeter landscape buffers.
2. Approval of and conformance to the Conditions of Approval for Variance (22-0174-VAR1) shall be required, if approved.
3. This approval shall be void two years from the date of final approval, unless exercised pursuant to the provisions of LVMC Title 19.16. An Extension of Time may be filed for consideration by the City of Las Vegas.
4. All development shall be in conformance with the site plan date stamped 07/26/22; landscape plan date stamped 09/07/22; and building elevations, date stamped 06/14/2022,
5. All necessary building permits shall be obtained and final inspections shall be completed in compliance with Title 19 and all codes as required by the Department of Building and Safety.
6. These Conditions of Approval shall be affixed to the cover sheet of any plan set submitted for building permit.
7. Pursuant to LVMC Title 19.08.040.G for commercial and industrial properties, a perimeter wall shall be constructed adjacent to any residential zoning district or property used solely for residential purposes. The wall or fence is intended to screen the commercial or industrial activity from the residential property, and shall be of a solid decorative material that is a minimum of six feet in height measured from the side of the commercial or industrial property. In no case shall the wall or fence exceed the overall height limitation applicable to the adjacent zoning district or property unless approved through a Variance or other applicable means. The overall height of a wall or fence shall be measured from the side with the greatest vertical exposure above finished grade.
8. A technical landscape plan, signed and sealed by a Registered Architect, Landscape Architect, Residential Designer or Civil Engineer, must be submitted prior to or at the same time application is made for a building permit. A permanent underground sprinkler system is required, which shall be permanently maintained in a satisfactory manner; the landscape plan shall include irrigation specifications. Installed landscaping shall not impede visibility of any traffic control device.
9. A fully operational fire protection system, including fire apparatus roads, fire hydrants and water supply, shall be installed and shall be functioning prior to construction of any combustible structures.
10. Prior to or at the time of submittal for any building permit, the applicant shall provide written verification by the FAA and/or the Clark County Department of Aviation of the following:

- a. Applicant is required to file a valid FAA Form 7460-1, "Notice of Proposed Construction or Alteration" with the FAA, in accordance with 14 CFR Part 77, or submit to the Clark County Director of Aviation a "Property Owner's Shielding Determination Statement" and request written concurrence from the Clark County Department of Aviation;
  - b. No Building Permit or other construction permit shall be issued for any structure greater than 35 feet above the surface of land that, based upon the FAA's 7460 airspace determination (the outcome of filing the FAA Form 7460-1) would (a) constitute a hazard to air navigation, (b) would result in an increase to minimum flight altitudes during any phase of flight (unless approved by the Department of Aviation), or (c) would otherwise be determined to pose a significant adverse impact on airport or aircraft operations.
  - c. Applicant is advised that FAA's airspace determinations are dependent on petitions by any interested party and the height that will not present a hazard as determined by the FAA may change based on these comments.
  - d. Applicant is advised that the FAA's airspace determinations include expiration dates and that the separate airspace determinations will be needed for construction cranes or other temporary equipment.
11. All development shall be in conformance with the site plan, landscape plan, and building elevations, date stamped 06/14/2022, except as amended by conditions herein.
  12. All City Code requirements and design standards of all City Departments must be satisfied, except as modified herein.

**Public Works**

13. Per the intent of a commercial subdivision, this site may connect to the on-site private sewer system. Alternatively, this site may connect to public sewer in Craig Road.
14. A Traffic Impact Analysis must be submitted to and approved by the Department of Public Works prior to the issuance of any building or grading permits, submittal of any construction drawings or the recordation of a Map subdividing this site, whichever may occur first. The Traffic Impact Analysis shall also include a pedestrian circulation/access plan to identify nearby pedestrian attractors and recommend measures to accommodate pedestrians, such as but not limited to pedestrian access, crosswalk, pedestrian activated flashers and temporary sidewalks. Comply with the recommendations of the approved Traffic Impact Analysis prior to occupancy of the site. Phased compliance will be allowed if recommended by the approved Traffic Impact Analysis. No recommendation of the approved Traffic Impact Analysis, nor compliance therewith, shall be deemed to modify or eliminate any condition of approval imposed by the Planning Commission or the City Council on the development of this site. A Master Traffic Impact analysis for the entire commercial subdivision may be used to address this condition.
15. A Drainage Plan and Technical Drainage Study must be submitted to and approved by the Department of Public Works prior to the issuance of any building or grading permits or submittal of any construction drawings, whichever may occur first. Provide and improve all drainageways recommended in the approved drainage plan/study. The developer of this site

shall be responsible to construct such neighborhood or local drainage facility improvements as are recommended by the City of Las Vegas Neighborhood Drainage Studies and approved Drainage Plan/Study concurrent with development of this site.

The Notice of Final Action was filed with the Las Vegas City Clerk on October 19, 2022.

Sincerely,



Seth T. Floyd  
Director of Community Development  
Department of Planning

STF:PL:ew

cc:

Rele Rolin and Moe Momeni  
Momeni Engineering  
3120 South Decatur Drive Suite 205  
Las Vegas, Nevada 89117