

CITY OF LAS VEGAS		DATE:
INTER-OFFICE MEMORANDUM		October 26, 2022
TO: Land Development Services Department of Building & Safety		FROM: Caitlyn Alcantara, P.E. <i>CA</i> Engineering Associate Department of Public Works
SUBJECT:	Technical Drainage Study for: Apricot & Roberta	COPIES TO: VTN Nevada
Cross Streets:	SWC of Apricot Lane & Roberta Drive	Porfirio Mora & Luis Jose
File Number:	F:\Depot\DSMemos\DS5588C.doc	Bart Anderson, P.E., DevCo
Parcel Number:	138-13-801-011	CCPW
Zoning Action:	21-0736-GPA1, 21-0736-ZON1, 21-0736-VAR1, 21-0736-VAR2, 21-0736-TMP1	
FEMA Flood Zone	YES	NO X
Proposed Storm Drain	YES	NO X

HISTORY	DATE RECEIVED	DATE REVIEWED	COMMENTS	REVIEW FEES	FEES PAID Payment Trn #
1 st Submittal	6/30/2022	7/7/2022	Not Approved	\$400	4858802: \$400
2 nd Submittal	8/17/2022	8/29/2022	Conditionally Approved	\$400	4929537: \$400
CCPW	10/6/2022	10/26/2022	Concurrence Received	N/C	N/C
TOTAL FEES (LDDRS):				\$800	----

REMARKS:

The Drainage Study for the subject project has been reviewed and:

X	is approved subject to conformance to all City standards and the following conditions:
	must be resubmitted or supplemented including the following:
	is conditionally approved subject to Clark County Regional Flood Control District concurrence.
	is conditionally approved subject to Clark County Public Works Department concurrence.

- The private street must be granted and labeled on the Final Map for this site as Public Utility Easements (P.U.E), Public sewer Easements, and Public Drainage Easements with private surface maintenance by Homeowner's Association.

NOTE: Please be advised that all land surface area disturbances over 1 acre or any area adjacent to a water way must submit to the *Nevada Division of Environmental Protection* a "Notice of Intent" to discharge that certifies a stormwater pollution prevention plan has been developed and is maintained on site; for inclusion in the Stormwater General Permit No. NVR100000. A phased construction unit in a contiguous subdivision is considered under construction until all stripped or disturbed surface areas have been covered by paving, building construction or planting. For more information, including forms and applications see <http://ndep.nv.gov/bwpc/storm01.htm> or call (775) 687-9429.

NOTE: Any future changes to the proposed design (or design assumptions) as outlined in the approved drainage study and attached preliminary grading plan which affect drainage must be addressed in a Drainage Study Update and accepted by the *City of Las Vegas Flood Control Section*. Additionally, conditional acceptance of a drainage study is valid for a period of one (1) year. If the proposed construction has not been completed in that time period, the *City of Las Vegas* reserves the right to require additional conditions and/or submission and acceptance of a complete drainage study update prior to further construction of a project.

END OF REMARKS
AYS/CAA

T/R/S: T20S/R60E/S13
AREA L13