

<b>CITY OF LAS VEGAS INTER-OFFICE MEMORANDUM</b>		<b>DATE:</b> November 28, 2022
<b>TO:</b> Land Development Services Department of Building & Safety		<b>FROM:</b> Albert Sung, P.E. Flood Control Project Engineer Department of Public Works
<b>SUBJECT:</b>	Drainage Study for:	<b>COPIES TO:</b>
<b>Thrive Townhomes – Update #1</b>		CVL Nevada, Inc.
<b>Cross Streets:</b>	NEC Shaumber Road and Hammer Lane	Ann Road I-215 Interchange LLC
<b>File Number:</b>	F:\Depot\DSMemos\DS5625A.doc	Bart Anderson, P.E., DevCo
<b>Parcel Number:</b>	126-36-101-008	CCRFCFCD
<b>Zoning Action:</b>	21-0593-ZON1; 21-0593-VAR1; 21-0593-VAC1 and 21-0593-TMP1	
<b>FEMA Flood Zone</b>	YES	NO <b>X</b>
<b>Proposed Storm Drain</b>	YES <b>X</b>	NO

HISTORY	DATE RECEIVED	DATE REVIEWED	COMMENTS	REVIEW FEES	FEES PAID Payment Trn #
1 <sup>st</sup> Submittal	12/2/2021	12/11/2021	Not Approved	\$400.00	4562462: \$400
2 <sup>nd</sup> Submittal	2/17/2022	3/7/2022	Not Approved	\$400.00	4656657: \$400
3 <sup>rd</sup> Submittal	3/17/2022	4/2/2022	Conditionally Approved	\$400.00	4699908: \$400
CCRFCFCD	9/6/2022	9/20/2022	Concurrence Recv'd	N/C	N/C
4 <sup>th</sup> Submittal	11/16/2022	11/28/2022	See Comments Below	\$400.00	5041884: \$400
<b>TOTAL FEES (LDDRS):</b>				<b>\$1,600.00</b>	<b>----</b>

**REMARKS:**

**4<sup>th</sup> Submittal: Update #1 done by a different engineer to address moving SDMH #3 for about 30' west**

The Drainage Study for the subject project has been reviewed and:

<b>X</b>	is approved subject to conformance to all City standards and the following conditions:
	must be resubmitted or supplemented including the following:
	is conditionally approved subject to Clark County Regional Flood Control District concurrence.
	is conditionally approved subject to Clark County Public Works Department concurrence.

**NOTE:** Any future changes to the proposed design (or design assumptions) as outlined in the approved drainage study and attached preliminary grading plan which affect drainage must be addressed in a Drainage Study Update and accepted by the *City of Las Vegas Flood Control Section*. Additionally, conditional acceptance of a drainage study is valid for a period of one (1) year. If the proposed construction has not been completed in that time period, the *City of Las Vegas* reserves the right to require additional conditions and/or submission and acceptance of a complete drainage study update prior to further construction of a project.

**NOTE:** Please be advised that all land surface area disturbances over 1 acre or any area adjacent to a water way must submit to the Nevada Division of Environmental Protection a "Notice of Intent" to discharge that certifies a stormwater pollution prevention plan has been developed and is maintained on site; for inclusion in the Stormwater General Permit No. NVR100000. A phased construction unit in a contiguous subdivision is considered under construction until all stripped or disturbed surface areas have been covered by paving, building construction or planting. For more information, including forms and applications see <http://ndep.nv.gov/bwpc/storm01.htm> or call (775) 687-9429.

**END OF REMARKS**  
OSK

T/R/S: T19S/R59E/S36  
AREA F-36