

## Emily Sidebottom

---

**From:** Bill Meyer  
**Sent:** Tuesday, November 1, 2022 2:43 PM  
**To:** Emily Sidebottom  
**Subject:** FW: PW22-18504 items  
**Attachments:** Fig 7.pdf; G1.pdf

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

FYI

I've already created the letter.

There will not be any fees due for this submittal.

---

**From:** Crissy Riland <Christine.Riland@ClarkCountyNV.gov>  
**Sent:** Tuesday, November 1, 2022 1:20 PM  
**To:** Bill Meyer <billm@taneycorp.com>  
**Subject:** PW22-18504 items

[EXTERNAL E-MAIL]

Hi Bill,

I am reviewing PW22-18504, Lamb & Owens, and need some items to finalize the study.

Can you please address the following and have the items delivered to me?

I will put the study on hold until I receive the information. This is a Supplement and can be delivered to the front counter addressed to "Crissy".

1. Provide the Standard Form 1 showing all APNs for the project.
2. Figure 7 – See attached.
  - a. Revise the basin boundary for DON1A. There is a high point in the entrance. If the common elements drain to Owens, revise those areas too.
  - b. Move the label for CD1 so you can see the flow arrow.
  - c. Where is cross-sections X & Y in the table?
  - d. Sections B & G in the table show the same description, "CDA + DON1", however they show different flows. Review and revise accordingly.
  - e. Address redlines and provide 1 copy.
3. Grading plans – See attached.
  - a. Show how the common elements in Basin DON1A areas drain.
  - b. Label CC & CLV boundaries.
  - c. Ensure the text at the top of Sheet G1 is not cut off.
  - d. Add Shaded Zone X to the Flood Zone Note.
  - e. Address all redlines and provide 2 copies, stamped, signed and dated.

Please call if you have any questions.

Thanks,  
Crissy



Crissy Riland, P.E.  
Senior Civil Engineer  
Clark County Department of Public Works  
500 S. Grand Central Parkway/Box 551799  
Las Vegas, NV 89155  
(702) 455-3254  
[Crissy@ClarkCountyNV.gov](mailto:Crissy@ClarkCountyNV.gov)