

<b>CITY OF LAS VEGAS INTER-OFFICE MEMORANDUM</b>		<b>DATE:</b> May 16, 2023
<b>TO:</b> Land Development Services Department of Building & Safety		<b>FROM:</b> Albert Sung, P.E. Flood Control Project Engineer Department of Public Works
<b>SUBJECT:</b> Drainage Study for: <b>Summerlin Storage – Update #1</b>		<b>COPIES TO:</b> Horrocks Engineers
<b>Cross Streets:</b>	NWQ of Rainbow Boulevard & Westcliff Drive	Summerlin Parkway Storage, LLC
<b>File Number:</b>	F:\Depot\DSMemos\DS5459G.doc	Bart Anderson, P.E., DevCo
<b>Parcel Number:</b>	138-27-802-001	CCRFCD
<b>Zoning Action:</b>	21-0538-EOT1 & 21-0538-EOT2	
<b>FEMA Flood Zone</b>	YES NO <b>X</b>	
<b>Proposed Storm Drain</b>	YES <b>X</b> NO	

HISTORY	DATE RECEIVED	DATE REVIEWED	COMMENTS	REVIEW FEES	FEES PAID Payment Trn #
1 <sup>st</sup> Submittal (Paid: 6/9/2021)	6/2/2021 & 6/9/2021	6/22/2021	Not Approved	\$400.00	4325787: \$400
2 <sup>nd</sup> Submittal	7/26/2021	8/17/2021	Not Approved	\$400.00	4383456: \$400
3 <sup>rd</sup> Submittal (Supplement)	11/2/2021	11/9/2021	Conditional Approval	N/C	N/C
CCRFCD	12/15/2021	12/29/2021	Concurrence Recv'd	N/C	N/C
4 <sup>th</sup> Submittal	3/16/2023	4/3/2023	Not Approved	\$100.00	5187807: \$100
5 <sup>th</sup> Submittal	4/27/2023	5/11/2023	Approved	\$400.00	5247748: \$400
Supplement	5/15/2023	5/16/2023	See Comments Below	N/C	N/C
<b>TOTAL FEES (LDDRS):</b>				<b>\$1,300.00</b>	<b>----</b>

**REMARKS:**

**Supplement: Recorded Drainage Easement Received**

4<sup>th</sup> & 5<sup>th</sup> Submittals: Update #1 & Addendum to add trees in the drainage channel

The Drainage Study for the subject project has been reviewed and:

<b>X</b>	is approved subject to conformance to all City standards and the following conditions:
	must be resubmitted or supplemented including the following:
	is conditionally approved subject to Clark County Regional Flood Control District concurrence.
	is conditionally approved subject to Clark County Public Works Department concurrence.

**NOTE:** Please be advised that all land surface area disturbances over 1 acre or any area adjacent to a water way must submit to the Nevada Division of Environmental Protection a "Notice of Intent" to discharge that certifies a stormwater pollution prevention plan has been developed and is maintained on site; for inclusion in the Stormwater General Permit No. NVR100000. A phased construction unit in a contiguous subdivision is considered under construction until all stripped or disturbed surface areas have been covered by paving, building construction or planting. For more information, including forms and applications see <http://ndep.nv.gov/bwpc/storm01.htm> or call (775) 687-9429.

**NOTE:** Any future changes to the proposed design (or design assumptions) as outlined in the approved drainage study and attached preliminary grading plan which affect drainage must be addressed in a Drainage Study Update and accepted by the *City of Las Vegas Flood Control Section*. Additionally, conditional acceptance of a drainage study is valid for a period of one (1) year. If the proposed construction has not been completed in that time period, the *City of Las Vegas* reserves the right to require additional conditions and/or submission and acceptance of a complete drainage study update prior to further construction of a project.

**END OF REMARKS**  
HDR/AYS

T/R/S: T20S/R60E/27  
AREA L-27