

 Keri Preisler

From: Peter Jackson <pjackson@LasVegasNevada.GOV>
Sent: Wednesday, September 7, 2022 9:39 AM
To: Glenn Blake; Chao, Paul
Cc: Curcuru, Chelsea; Gerald Burke; Keri Preisler; Paul Valentine; Oh-Sang Kwon; Albert Sung; Pete Laas P.E.
Subject: Nighthawk (L22-00473)
Follow Up Flag: Follow up
Flag Status: Flagged

Caution

This email originated from outside of WLB.

Glenn,

Flood Control understands that improvement plans have been modified back to reflect the approved drainage study. As you are aware, the plans need to match the approved drainage study. **Any further modifications will require a Drainage Study Update.**

As discussed, Flood Control requires you to provide a Supplement to the Drainage Study (DS5535).

The supplement Cover Letter needs to explain the changes and the corresponding plan sheets.

- Note the change in storm drain pipe material from RCP to C900 in various locations due to separation requirements.
- Note that there are minor shifts (less than X' – call out the maximum shift) in the storm drain manhole locations. These minor shifts do not change the overall storm drain conveyance.
- The Grading Plan Certification Note has been revised to reflect the drainage study is on file with the “City of Las Vegas” instead of Clark County.

Provide the corresponding Plan Sheets (full size, wet stamped).

All GR – Sheets

SD-01

PP-01, PP-04, PP-06, PP-07

Provide an electronic copy of the entire Supplemental submittal.

Please advise when this Supplement will be delivered to me for processing. The Supplement does not require a fee. Please give me a call if you have any questions.

Peter Jackson, CFM

Senior Engineering Associate
City of Las Vegas | Dept. of Public Works
City Engineering Division, Flood Control Section
City Hall, 5th Floor
495 S Main St. | Las Vegas, Nevada 89101



Work: 702-229-5266 Link: www.lasvegasnevada.gov
pjackson@lasvegasnevada.gov