

CITY OF LAS VEGAS INTER-OFFICE MEMORANDUM		DATE: October 12, 2023
TO: Land Development Services Department of Building & Safety		FROM: Albert Sung, P.E. Flood Control Project Engineer Department of Public Works
SUBJECT:	Drainage Study for:	COPIES TO:
	Sunrise Mountain Plaza Site Modification	GCW, Inc.
Cross Streets:	SWC of Bonanza Road & Nellis Boulevard	BRFI Las Vegas, LLC
File Number:	F:\Depot\DSMemos\DS5687D.doc	Bart Anderson, P.E., DevCo
Parcel Number:	140-32-518-001	CCRFC
Zoning Action:	21-0110-SDR1	CCPW
FEMA Flood Zone	YES	NO X
Proposed Storm Drain	YES	NO X

HISTORY	DATE RECEIVED	DATE REVIEWED	COMMENTS	REVIEW FEES	FEES PAID Payment Trn #
1 st Submittal	6/29/2023	7/19/2023	Not Approved	\$400.00	5333224: \$400
2 nd Submittal	8/9/2023	8/22/2023	Conditional Approval	\$400.00	5391372: \$400
CCRFC	9/26/2023	10/5/2023	Concurrence Recv'd	N/C	N/C
CCPW	10/11/2023	10/12/2023	Concurrence Recv'd	N/C	N/C
			TOTAL FEES (LDDRS):	\$800.00	----

REMARKS:

The Drainage Study for the subject project has been reviewed and:

X	is approved subject to conformance to all City standards and the following conditions:
	must be resubmitted or supplemented including the following:
	is conditionally approved subject to Clark County Regional Flood Control District concurrence.
	is conditionally approved subject to Clark County Public Works Department concurrence.

- Per Condition #11 of Application **21-0110-SDR1**, quote: "Coordinate with the *Environmental Compliance & Enforcement* staff of the *Department of Public Works* to locate any required grease interceptor and sand/oil interceptors in acceptable locations prior to submittal of sewer-related plans. Comply with the recommendations and requirements of the *Environmental Compliance & Enforcement* staff prior to issuance of permits. The team may be contacted at 702-229-6594 or emailed at ece@lasvegasnevada.gov" – end quote.

Provide proof of approval from the *Environmental Compliance & Enforcement* staff such as a letter or an email prior to the final approval of the improvement plans.

***** The City of Las Vegas Flood Control is standardizing the file naming of drainage studies and plans during the digitizing process. When saving the project files in the CD or thumb drive, please follow the system below:**

If drainage study only contains one combined file, use the following naming convention in Document Title:

1st Submittal DS and Plans (for first and original submittal);

2nd Submittal DS and Plans (for second submittal (addendum #1)) etc.

If drainage study contains multiple files, use the following naming convention in Document Title:

1st Submittal DS (for the report of the drainage study)

1st Submittal Plan 1 (could be the drainage condition maps)

1st Submittal Plan 2 (could be the improvement plans) etc.

NOTE: Please be advised that all land surface area disturbances over 1 acre or any area adjacent to a water way must submit to the *Nevada Division of Environmental Protection* a "Notice of Intent" to discharge that certifies a stormwater pollution prevention plan has been developed and is maintained on site; for inclusion in the Stormwater General Permit No. NVR100000. A phased construction unit in a contiguous subdivision is considered under construction until all stripped or disturbed surface areas have been covered by paving, building construction or planting. For more information, including forms and applications see <http://ndep.nv.gov/bwpc/storm01.htm> or call (775) 687-9429.

NOTE: Any future changes to the proposed design (or design assumptions) as outlined in the approved drainage study and attached preliminary grading plan which affect drainage must be addressed in a Drainage Study Update and accepted by the *City of Las Vegas Flood Control Section*. Additionally, final approval of a drainage study is valid for a period of one (1) year. If the proposed construction has not been completed in that time period, the *City of Las Vegas* reserves the right to require additional conditions and/or submission and acceptance of a complete drainage study update prior to further construction of a project.

END OF REMARKS

AYS

T/R/S: T20S/R62E/32

AREA N-32