

| | | |
|--|---|--|
| CITY OF LAS VEGAS INTER-OFFICE MEMORANDUM | | DATE: April 22, 2024 |
| TO: Land Development Services Department of Building & Safety | | FROM: Tyler Key Flood Control Section Department of Public Works |
| SUBJECT: | Drainage Study for: | COPIES TO: |
| Skye Canyon Parcel 5.06 – Phase 4 | | Westwood |
| Cross Streets: | SWC of Sheep Mountain Parkway & Iron Mountain Road | Century Communities of Nevada, LLC |
| File Number: | F:\Depot\DSMemos\DS5743B.doc | Bart Anderson, P.E.; DevCo |
| Parcel Number: | 126-12-101-006 | CCRFCDD |
| Zoning Action: | 22-0412-TMP1 | |
| FEMA Flood Zone | YES | NO X |
| Proposed Storm Drain | YES | NO X |

| HISTORY | DATE RECEIVED | DATE REVIEWED | COMMENTS | REVIEW FEES | FEES PAID Payment Trn # |
|----------------------------|---------------|---------------|---------------------------------|-----------------|----------------------------|
| 1 st Submittal | 2/22/2024 | 3/19/2024 | Conditionally Approved | \$400.00 | 5639731: \$400 |
| CCRFCDD | 4/16/2024 | 4/22/2024 | CCRFCDD Concurrence Received | N/C | N/C |
| TOTAL FEES (LDDRS): | | | | \$400.00 | ---- |

REMARKS:

Per 22-0412-TMP1: No permits shall be issued for this site and no Final Maps for this site shall record until all remaining Master Developer Infrastructure identified in the Skye Canyon Development Agreement is constructed or guaranteed to the satisfaction of the Director of Public Works.

The Drainage Study for the subject project has been reviewed and:

| | |
|----------|--|
| X | is approved subject to conformance to all City standards and the following conditions: |
| | must be resubmitted or supplemented including the following: |
| | is conditionally approved subject to Clark County Regional Flood Control District concurrence. |
| | is conditionally approved subject to Clark County Public Works Department concurrence. |

- No permits shall be issued for this site and Final Maps for this site shall record until all remaining Master Developer infrastructure identified in the ***Skye Canyon Development Agreement*** is constructed or guaranteed to the satisfaction of the **Director of the Public Works Department**.
- The study assumes the storm drain infrastructure proposed by the *Technical Drainage Study for Iron Mountain* is in place. Substantial completion of the Iron Mountain infrastructure facilities is required prior to approval of the improvement plans for this study.
- The study assumes the storm drain infrastructure proposed by the *Technical Drainage Studies for Skye Canyon Parcel 5.06 Phase 1* are in place and functioning. Substantial completion of the *Skye Canyon Parcel 5.06 Phase 1 Infrastructure* facilities is required prior to residential occupancy permits.

4. Add a new drainage study number DS05743 to DS compliance note.
5. Provide the note below as *Standard Note No. 6* to the “*Las Vegas Valley Construction Site BMP Guidelines*” notes column on the *Grading Plan Sheet* and change entity to the *City of Las Vegas*.

Post-Construction BMPs (PCBMPs) / Control Measures noted on the Grading Plans are mandatory permanent regulatory stormwater pollution controls. These PCBMPs must be installed per the approved plans and must be permanently maintained.

NOTE: Please be advised that all land surface area disturbances over 1 acre or any area adjacent to a water way must submit to the Nevada Division of Environmental Protection a "Notice of Intent" to discharge that certifies a stormwater pollution prevention plan has been developed and is maintained on site; for inclusion in the Stormwater General Permit No. NVR100000. A phased construction unit in a contiguous subdivision is considered under construction until all stripped or disturbed surface areas have been covered by paving, building construction or planting. For more information, including forms and applications see <http://ndep.nv.gov/bwpc/storm01.htm> or call (775) 687-9429.

NOTE: Any future changes to the proposed design (or design assumptions) as outlined in the approved drainage study and attached preliminary grading plan which affect drainage must be addressed in a Drainage Study Update and accepted by the *City of Las Vegas Flood Control Section*. Additionally, final approval of a drainage study is valid for a period of one (1) year. If the proposed construction has not been completed in that time period, the *City of Las Vegas* reserves the right to require additional conditions and/or submission and acceptance of a complete drainage study update prior to further construction of a project.

***** The City of Las Vegas Flood Control is standardizing the file naming of drainage studies and plans during the digitizing process. When saving the project files in the CD or thumb drive, please follow the system below:**

If drainage study only contains one combined file, use the following naming convention in Document Title:

1st Submittal DS and Plans (for first and original submittal);

2nd Submittal DS and Plans (for second submittal (addendum #1)) etc.

If drainage study contains multiple files, use the following naming convention in Document Title:

1st Submittal DS (for the report of the drainage study)

1st Submittal Plan 1 (could be the drainage condition maps)

1st Submittal Plan 2 (could be the improvement plans) etc.

END OF REMARKS
OSK

T/R/S: T19S/R59E/12
AREA F-12