

November 19, 2021

Mr. Albert Sung, Project Engineer  
City of Las Vegas, Public Works Department / Flood Control  
495 S. Main Street  
Las Vegas, NV 89101

**SUBJECT: Taco Bell (Pad H) @ Skye Canyon – Drainage Update Letter**

Mr. Sung,

The original Drainage Study (CLV #4812) and Civil Engineering Plans for the subject project (CLV #107V6745 Hansen #66211) established the finished floor elevation for Pad H at 2789.75'. The proposed Taco Bell project will meet the already approved finished floor elevation and is set at 2789.75'. Positive drainage is provided and the drainage flow paths established in the approved study and civil plans have not changed as depicted on the attached grading plan.

Please let me know if you have any questions or require any additional information.

Respectfully,



Brandon A Potts, P.E.  
Principal

Attachments: Standard Form 1  
Taco Bell (Pad H) Grading Plan