

CITY OF LAS VEGAS INTER-OFFICE MEMORANDUM		DATE: June 18, 2024
TO: Land Development Services Department of Building & Safety		FROM: Albert Sung, P.E. Flood Control Project Engineer Department of Public Works
SUBJECT:	Drainage Study for:	COPIES TO:
Kyle Canyon Gateway Unit 1 & Unit 3 Phase 2 Offsites – Update #4		Westwood Professional Services
Cross Streets:	Michelli Crest Way and Kyle Canyon Road	Tri-Pointe Homes
File Number:	F:\Depot\DSMemos\DS5537G.doc	Bart Anderson, P.E., DevCo
Parcel Number:	126-01-601-008, -009, -010, -011, 126-01-701-001, -002, -003, -009	
Zoning Action:		
FEMA Flood Zone	YES NO X	
Proposed Storm Drain	YES X NO	

HISTORY	DATE RECEIVED	DATE REVIEWED	COMMENTS	REVIEW FEES	FEES PAID Payment Trn #
1 st Submittal	12/28/2021	1/10/2022	Not Approved	\$400.00	4595296: \$400
2 nd Submittal	2/8/2022	2/25/2022	Conditional Approval	\$400.00	4643180: \$400
CCRFCD	3/29/2022	3/30/2022	Concurrence Recv'd	N/C	N/C
Update #1	8/23/2022	8/23/2022	Approved	\$100.00	4924299: \$100
Update #2	4/12/2023	5/1/2023	Approved	\$100.00	5229835: \$100
Update #3	1/8/2024	1/11/2024	Approved	\$100.00	5586949: \$100
Update #4	6/3/2024	6/17/2024	See Comments Below	\$100.00	5793018: \$100
TOTAL FEES (LDDRS):				\$1,200.00	----

REMARKS:

Update #4: Remove roadway improvements to Ruston Road alignment to match KCG West

UPDATE #3: Relocate interim sump pit to provide adequate separation for proposed sewer line.

The Drainage Study for the subject project has been reviewed and:

X	is approved subject to conformance to all City standards and the following conditions: must be resubmitted or supplemented including the following:
	is conditionally approved subject to Clark County Regional Flood Control District concurrence.
	is conditionally approved subject to Clark County Public Works Department concurrence.

***** The City of Las Vegas Flood Control is standardizing the file naming of drainage studies and plans during the digitizing process. When saving the project files in the CD or thumb drive, please follow the system below:**

If drainage study only contains one combined file, use the following naming convention in Document Title:

1st Submittal DS and Plans (for first and original submittal);

2nd Submittal DS and Plans (for second submittal (addendum #1)) etc.

If drainage study contains multiple files, use the following naming convention in Document Title:

1st Submittal DS (for the report of the drainage study)

1st Submittal Plan 1 (could be the drainage condition maps)

1st Submittal Plan 2 (could be the improvement plans) etc.

NOTE: Please be advised that all land surface area disturbances over 1 acre or any area adjacent to a water way must submit to the *Nevada Division of Environmental Protection* a "Notice of Intent" to discharge that certifies a stormwater pollution prevention plan has been developed and is maintained on site; for inclusion in the Stormwater General Permit No. NVR100000. A phased construction unit in a contiguous subdivision is considered under construction until all stripped or disturbed surface areas have been covered by paving, building construction or planting. For more information, including forms and applications see <http://ndep.nv.gov/bwpc/storm01.htm> or call (775) 687-9429.

NOTE: Any future changes to the proposed design (or design assumptions) as outlined in the approved drainage study and attached preliminary grading plan which affect drainage must be addressed in a Drainage Study Update and accepted by the *City of Las Vegas Flood Control Section*. Additionally, final approval of a drainage study is valid for a period of one (1) year. If the proposed construction has not been completed in that time period, the *City of Las Vegas* reserves the right to require additional conditions and/or submission and acceptance of a complete drainage study update prior to further construction of a project.

END OF REMARKS
AYS

T/R/S: T19S/R59E/01
AREA F-01