

<b>CITY OF LAS VEGAS INTER-OFFICE MEMORANDUM</b>		<b>DATE:</b> July 23, 2024
<b>TO:</b> Land Development Services Department of Building & Safety		<b>FROM:</b> Albert Sung, P.E. Flood Control Project Engineer Department of Public Works
<b>SUBJECT:</b>	Drainage Study for:	<b>COPIES TO:</b>
	<b>Overlook - Summerlin Village 25 – Parcel C - Update</b>	GCW Engineers / Surveyors
<b>Cross Streets:</b>	SEC of Sky Vista Drive & Redpoint Drive	Pardee Homes
<b>File Number:</b>	F:\Depot\DSMemos\DS5266D.doc	Bart Anderson, P.E., DevCo
<b>Parcel Number:</b>	137-27-110-001	
<b>Zoning Action:</b>	TMP-78246	
<b>FEMA Flood Zone</b>	YES NO <b>X</b>	
<b>Proposed Storm Drain</b>	YES <b>X</b> NO	

HISTORY	DATE RECEIVED	DATE REVIEWED	COMMENTS	REVIEW FEES	FEES PAID Payment Trn #
1 <sup>st</sup> Submittal	3/30/2020	4/23/2020	Not Approved	\$400.00	3793343: \$400
2 <sup>nd</sup> Submittal (Paid on 6/10/2020)	6/4/2020	6/24/2020	Approved	\$400.00	3878753: \$400
3 <sup>rd</sup> Submittal (Paid on 7/10/2020)	7/7/2020	7/21/2020	Approved	\$100.00	3911952: \$100
4 <sup>th</sup> Submittal	7/16/2024	7/23/2024	See Comments Below	\$100.00	5845237: \$100
			<b>TOTAL FEES (LDDRS):</b>	<b>\$1,000.00</b>	----

**REMARKS:**

**4<sup>th</sup> Submittal: Update to add a 15.65'-wide public drainage easement adjacent to "E5" as recorded in FMP-100037**

**3<sup>rd</sup> Submittal: Update to revise the finished floor elevations of Lots 14-18, 20-21 and 59-62**

The Drainage Study for the subject project has been reviewed and:

<b>X</b>	is approved subject to conformance to all City standards and the following conditions:
	must be resubmitted or supplemented including the following:
	is conditionally approved subject to Clark County Regional Flood Control District concurrence.
	is conditionally approved subject to Clark County Public Works Department concurrence.

1. The proposed additional 15.65'-public drainage easement (privately maintained by HOA) must be recorded by separate document prior to the final approval of the improvement plans.

**\*\*\* The City of Las Vegas Flood Control is standardizing the file naming of drainage studies and plans during the digitizing process. When saving the project files in the CD or thumb drive, please follow the system below:**

**If drainage study only contains one combined file, use the following naming convention in Document Title:**

**1<sup>st</sup> Submittal DS and Plans (for first and original submittal);**

**2<sup>nd</sup> Submittal DS and Plans (for second submittal (addendum #1)) etc.**

**If drainage study contains multiple files, use the following naming convention in Document Title:**

**1<sup>st</sup> Submittal DS (for the report of the drainage study)**

**1<sup>st</sup> Submittal Plan 1 (could be the drainage condition maps)**

**1<sup>st</sup> Submittal Plan 2 (could be the improvement plans) etc.**

**NOTE:** Please be advised that all land surface area disturbances over 1 acre or any area adjacent to a water way must submit to the *Nevada Division of Environmental Protection* a "Notice of Intent" to discharge that certifies a stormwater pollution prevention plan has been developed and is maintained on site; for inclusion in the Stormwater General Permit No. NVR100000. A phased construction unit in a contiguous subdivision is considered under construction until all stripped or disturbed surface areas have been covered by paving, building construction or planting. For more information, including forms and applications see <http://ndep.nv.gov/bwpc/storm01.htm> or call (775) 687-9429.

**NOTE:** Any future changes to the proposed design (or design assumptions) as outlined in the approved drainage study and attached preliminary grading plan which affect drainage must be addressed in a Drainage Study Update and accepted by the *City of Las Vegas Flood Control Section*. Additionally, final approval of a drainage study is valid for a period of one (1) year. If the proposed construction has not been completed in that time period, the *City of Las Vegas* reserves the right to require additional conditions and/or submission and acceptance of a complete drainage study update prior to further construction of a project.

**END OF REMARKS**

ays

T/R/S: T20S/R59E/27

AREA K-27