

CITY OF LAS VEGAS INTER-OFFICE MEMORANDUM			DATE: August 5, 2024
TO: Land Development Services Department of Building & Safety			FROM: Albert Sung, P.E. Flood Control Project Engineer Department of Public Works
SUBJECT:	Drainage Study for: Racel and Tenaya – Update #3		COPIES TO: Taney Engineering
Cross Streets:	SWC of Tenaya Way & Racel Street		Andrew Acuna
File Number:	F:\Depot\DSMemos\DS5105E.doc		Bart Anderson, P.E., DevCo
Parcel Number:	125-10-404-001 & -002		CCPW
Zoning Action:	TMP-74347		
FEMA Flood Zone	YES	NO X	
Proposed Storm Drain	YES X	NO	

HISTORY	DATE RECEIVED	DATE REVIEWED	COMMENTS	REVIEW FEES	FEES PAID Payment Trn #
1 st Submittal	2/21/2019	3/20/2019	Not Approved	\$400.00	\$400
2 nd Submittal	4/11/2019 & 5/9/2019	5/1/2019 & 5/13/2019	Conditional Approval	\$400.00	1321577: \$400
3 rd Submittal	9/12/2019	10/1/2019	CCPW Concurrence	\$100.00	3565912: \$100
4 th Submittal	2/6/2024	2/27/2024	Approved	\$100.00	5621383: \$100
5 th Submittal	7/29/2024	8/5/2024	See Comments Below	\$100.00	5863625: \$100
TOTAL FEES (LDDRS):				\$1,100.00	----

REMARKS:

5th Submittal: Update #3

4th Submittal: Update #2 to Re-Validate the previously approved drainage study

3rd Submittal: Update #1 to address CCPW comments

The Drainage Study for the subject project has been reviewed and:

X	is approved subject to conformance to all City standards and the following conditions:
	must be resubmitted or supplemented including the following:
	is conditionally approved subject to Clark County Regional Flood Control District concurrence.
	is conditionally approved subject to Clark County Public Works Department concurrence.

1. The proposed site includes a 20-foot equestrian trail along *Racel Street* and *Tenaya Way*. The detail of the trail section must include the 10-foot concrete sidewalk and landscape improvements approved by the *City of Las Vegas Comprehensive Planning*. The engineer must send one copy of the Grading Plans and Detail sheet to *Comprehensive Planning* at the *City of Las Vegas* for review and approval. Provide a copy of the *Planning Department* approval of the 20-foot equestrian trail prior to final approval of improvement plans. The proposed trail must also be granted as a "Public Drainage Easement to be Privately Maintained" on the final map prior to final approval of improvement plans.

***** The City of Las Vegas Flood Control is standardizing the file naming of drainage studies and plans during the digitizing process. When saving the project files in the CD or thumb drive, please follow the system below:**

If drainage study only contains one combined file, use the following naming convention in Document Title:

1st Submittal DS and Plans (for first and original submittal);

2nd Submittal DS and Plans (for second submittal (addendum #1)) etc.

If drainage study contains multiple files, use the following naming convention in Document Title:

1st Submittal DS (for the report of the drainage study)

1st Submittal Plan 1 (could be the drainage condition maps)

1st Submittal Plan 2 (could be the improvement plans) etc.

NOTE: Please be advised that all land surface area disturbances over 1 acre or any area adjacent to a water way must submit to the *Nevada Division of Environmental Protection* a "Notice of Intent" to discharge that certifies a stormwater pollution prevention plan has been developed and is maintained on site; for inclusion in the Stormwater General Permit No. NVR100000. A phased construction unit in a contiguous subdivision is considered under construction until all stripped or disturbed surface areas have been covered by paving, building construction or planting. For more information, including forms and applications see <http://ndep.nv.gov/bwpc/storm01.htm> or call (775) 687-9429.

NOTE: Any future changes to the proposed design (or design assumptions) as outlined in the approved drainage study and attached preliminary grading plan which affect drainage must be addressed in a Drainage Study Update and accepted by the *City of Las Vegas Flood Control Section*. Additionally, final approval of a drainage study is valid for a period of one (1) year. If the proposed construction has not been completed in that time period, the *City of Las Vegas* reserves the right to require additional conditions and/or submission and acceptance of a complete drainage study update prior to further construction of a project.

END OF REMARKS
JKS/AYS

T/R/S: T19S/R60E/10
AREA G-10